



**CITY OF LOS ANGELES**



**Title 24, California Code of Regulations  
Accessibility Regulations  
Supplemental Correction List No. 2  
(Effective 11-01-2002)**

**Group "A" Occupancies (Assemble Halls, Dining & Drinking, Etc.)  
Group "E", "H", & "I" Occupancies and Outdoor Facilities  
(Educational, Hazardous, Medical & Recreational Facilities)**

P.C. # \_\_\_\_\_

**ASSEMBLY OCCUPANCIES**

NOTE: Wheelchair areas shall be an integral part of any fixed seating plan, and shall be accessible from the main lobby or a primary entrance.

- ( 1104B.3.2)
- 1. Provide \_\_\_\_\_ seats/spaces for people using wheelchairs.  
( 1104B.3.4, T11B-1)

**Table 11B-1**

| Total Seating Capacity | Total # of wheelchair seating spaces required                       |
|------------------------|---|
| 4-26                   | 1   |
| 27-50                  | 2   |
| 51-300                 | 4   |
| 301-500                | 6   |
| 501 & over             | 6 plus 1 additional for each total seating capacity increase of 100 |

- 2. One percent, but not less than one, of all fixed seats shall be aisle seats with no armrests on the aisle side, or removable or folding armrests on the aisle side. Each such seat shall be identified by a sign or marker. Signage notifying patrons of the availability of such seats shall be posted at the ticket office. ( 1104B.3.4.1)
- 3. Accessible seating or accommodations in places of public amusement and resort (theaters, concert halls and stadiums) shall be provided in a variety of locations so as to provide persons with disabilities a choice of admission prices and lines of sight otherwise available to members of the general public. ( 1104B.3.3)
- 4. Wheelchair areas shall be an integral part of any fixed seating plan and shall be arranged so as to provide persons with disabilities a choice of admission prices and lines of sight comparable of those for members of the general public. When the seating capacity exceeds 300, wheelchair spaces shall be provided in more than one location and must comply with Sect. 1104B.3.3. (1104B.3.5)
- 5. At least one companion fixed seat shall be provided next to each wheelchair seating area. ( 1104B.3.5)
- 6. Each wheelchair area shall adjoin an accessible route. ( 1104B.3.5)
- 7. Each wheelchair location shall be level and provide a minimum clear floor or ground space of 33" in width and 60" in depth for side

access, or 48" in depth for front or rear access.  
( 1104B.3.4.3 & 1104B.3.6, Fig. 11B-15)

- 8. Readily removable seats may be installed in wheelchair spaces when such spaces are not being used to accommodate wheelchair users. ( 1104B.3.7)
- 9. Provide \_\_\_\_\_ seats for semi-ambulant persons (at least 1% of the total seating but no fewer than two) which provide at least 24" of clear leg space between the front of the seat to the nearest obstruction or to the back of the seat immediately in front (in addition to spaces provided for wheelchair users). ( 1104B.3.8)
- 10. An accessible route shall connect wheelchair seating locations with performing areas, including stages, arena floors, dressing rooms, locker rooms, and other spaces used by performers. ( 1104B.3.10)
- 11. Stages, enclosed and unenclosed platforms, and Orchestra pits shall be made accessible to persons with disabilities. ( 1104B.3.11)
- 12. Customer and employee sides of ticket booths and of concession and refreshment sales facilities shall be made accessible to persons with disabilities. ( 1104B.3.12 )
- 13. The customer side of a ticket booth shall be, and employee side may be, accessible to persons with disabilities (stadiums, grandstands, bleachers, athletic pavilion, gymnasiums, and miscellaneous sport-related facilities). ( 1104B.4.2)
- 14. Participation areas and clubrooms shall be accessible to person with disabilities. Provide wheelchair access to \_\_\_\_\_. ( 1104B.4.3 & 1104.B.4.4)
- 15. **Swimming pool deck areas must be accessible, and a mechanism to assist persons with disabilities in gaining entry into the pool and in exiting from the pool shall be provided. Mechanism shall meet requirements of Section 1104B.4.3.4. (1104B.4.3.4)**
- 16. Spectator and/or participant sanitary and/or locker facilities shall be accessible to persons with disabilities. ( 1104B.4.5)

**ASSISTIVE-LISTENING SYSTEM IN ASSEMBLY OCCUPANCIES**

NOTE: Types of Assistive-Listening Systems include, but are not limited to, audio-induction loops, radio frequency systems (AM or FM), and infrared transmission. ( 1104B.2.2)

NOTE: The requirements for Assistive-Listening Systems do not apply to systems used exclusively for paging, or background music, or a combination of these two uses. ( 1104B.2)

- 1. Assembly areas, conference rooms and meeting rooms shall be provided with assistive-listening systems for people with hearing impairments. ( 1104B.2)

2. Provide \_\_\_\_\_ personal receivers for people with hearing impairments (at least 4% of the total number of seats but no fewer than two). ( 1104B.2.1)
3. If the assistive-listening system provided is limited to specific areas or seats, then such areas or seats shall be within a 50-foot viewing distance of the performing area. ( 1104B.2.3)
4. A sign which includes the International Symbol of Access for Hearing Impaired and wording that states "Assistive-Listening System Available" shall be posted in a prominent place indicating the availability of assistive-listening devices. ( 1104B.2.4, Fig 11B-14B)
5. If portable assistive-listening systems are used for conference or meeting rooms, the system may serve more than one room. However, permanently installed assistive-listening systems are required in areas if (1) they accommodate at least 50 persons, or have audio-amplification systems, and (2) they have fixed seating. ( 1104B.2.6)

### **RELIGIOUS FACILITIES**

1. Wheelchair access shall be provided to sanctuary areas, raised platforms, choir rooms, choir lofts, performing areas, and other similar areas. ( 1104B.6.2.2)
2. Assembly areas and enclosed and unenclosed platforms and stages in assembly areas shall be made accessible to persons with disabilities. ( 1104B.6.3)
3. Provide \_\_\_\_\_ spaces for people using wheelchairs at \_\_\_\_\_. ( 1104B.6.2.1 & 1104B.3.1)
4. Classrooms and offices shall have entry doors that conform to the requirements in Section 1003.3.1. (1104B.6.4)

### **DINING, BANQUET, & BAR FACILITIES**

NOTE: In existing dining, banquet and bar facilities, when the enforcing agency determines that compliance with this section would create an unreasonable hardship, an exception shall be granted provided that a minimum of 75 percent of the dining, banquet and bar area shall be a common level throughout or shall be connected by pedestrian ramps, passenger elevators or special lifts. ( 1104B.5)

1. Wheelchair access shall be provided to all areas where a different type of functional activity occurs. Provide wheelchair access to \_\_\_\_\_. ( 1104B.5.3)
2. Provide \_\_\_\_\_ seats/spaces for people using wheelchairs (at least one space for each 20 seats, with at least one space per functional area) integrated with general seating to avoid having one area specifically highlighted as the area for person with disabilities. ( 1104B.5.4)
3. Access to disabled seating shall be provided with main aisles not less than 36" in clear width. ( 1104B.5.4)
4. Food service aisles shall be a minimum of 36" in clear width with a preferred width of 42" where passage of stopped wheelchairs by pedestrians is desired. Tray slides shall be mounted no higher than 34" above the floor. If self-service shelves are provided, a reasonable portion must be within the ranges shown in Fig. 11B-16. ( 1104B.5.5)
5. Tableware, dishware, condiments, food and beverage display shelves and dispensing devices, when located on tables or counter tops, shall be placed 28" to 34" above the adjacent floor. These items, when located on shelves, shall be placed no higher than 54" above the adjacent floor, where not required to reach over an obstruction, and no higher than 46" above the adjacent floor when required to reach over an obstruction. An obstruction which a disabled person is required to reach over shall be no higher than 34"

above the adjacent floor with a horizontal reach over the obstruction of no more than 24". ( 1104B.5.6, Fig 11B-17)

6. Access to food preparation areas shall comply with the provisions for entrance doors and doorways in Section 1004, and aisles in Section 1004.3.2 and 1004.3.2.2. ( 1104B.5.8)

### **EDUCATIONAL & LIBRARY FACILITIES**

1. Teaching facility cubicles, study carrels, etc., shall have 5%, but always at least one cubicles or carrel in each group (language, dental, audio-visual, typing, drafting, darkrooms, etc.) made accessible to and usable by persons with disabilities in compliance with Sections 1118B & 1122B. ( 1106B.3)
2. Laboratory rooms shall have at least one work station and at least 5% of all work stations accessible. ( 1106B.2)
3. Library general use areas such as those housing card files, book stacks, periodicals, reading and reference areas, information desks, circulation counters, etc., shall be made accessible. ( 1106B.4.1)
4. Open book stacks available for customer use may be of normal heights and shall have main aisles no less than 44" in width and side, range and end aisles no less than 36" in width. ( 1106B.4.2)
5. Reach heights at card catalogs and magazine displays, shall be between 15" and 48" for forward reach and between 9" and 54" for side reach with reach over obstruction in accordance with Figure 11B-5C & 11B-5D. ( 1106B.4.4)
6. Unless an attendant is available to assist persons with disabilities, all book shelving shall be located not more than 54" above the floor. (1106B.4.3)

### **HAZARDOUS FACILITIES**

1. Areas that are used by the public as customers, clients, visitors or which are potential places of employment, shall be accessible. ( 1108B)

### **MEDICAL CARE FACILITIES**

1. At least one accessible entrance shall be protected from the weather by a canopy or roof overhang. Such entrances shall incorporate a passenger loading zone. Passenger loading zones shall provide an access aisle at least 60" wide and 20' long adjacent and parallel to the vehicle pull-up space. If there are curbs between the access aisle and the vehicle pull-up space, then a curb ramp complying with Sections 1127B.5 and 1131B shall be provided. Vehicle standing spaces and access aisles shall be level with surface slopes not exceeding 1:50 in all directions. A minimum vertical clearance of 114" at accessible passenger loading zones and along vehicle access routes to such areas from site entrance shall be provided. ( 1109B.2)
2. Long-Term-Care facilities, including skilled nursing facilities, intermediate care facilities, bed and care, and nursing homes shall have at least 50% of patient bedrooms and toilet rooms, and all public use and common use areas, accessible. ( 1109B.3.1)
3. General purpose hospitals, psychiatric facilities, and detoxification facilities shall have at least 10% of patient bedrooms and toilets, and all public use and common use areas accessible. ( 1109B.3.2)
4. Hospitals and rehabilitation facilities that specialize in treating conditions that affect mobility, or units within either that specialize in treating conditions that affect mobility shall have all patient bedrooms and toilets and all public use and common use areas accessible. ( 1109B.3.3)

