

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

VAN AMBATIELOS
PRESIDENT

E. FELICIA BRANNON
VICE PRESIDENT

JOSELYN GEAGA-ROSENTHAL
GEORGE HOVAGUIMIAN
JAVIER NUNEZ

Mark Arndt
Forever Stainless Steel
10918 Emiline Street
La Vista, NE 68128

Telephone: 866-774-3837

Models:

See the Attached List of Models

CITY OF LOS ANGELES
CALIFORNIA



ERIC GARCETTI
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

FRANK M. BUSH
GENERAL MANAGER
SUPERINTENDENT OF BUILDING

OSAMA YOUNAN, P.E.
EXECUTIVE OFFICER

File Number: M-110099

Effective Date: 08/30/2017

Expiration Date: 09/01/2018

Manufacturer: FOREVER STAINLESS STEEL

Item: ANIMAL / PET BATHTUB

PLEASE REFER TO THE APPLICATION NUMBER ON ALL CORRESPONDENCE, PHONE CALLS & SAMPLES

The item processed under the above file number has been tested, examined and found to comply with applicable Los Angeles Plumbing Code (LAPC) and/or Los Angeles Mechanical Code (LAMC) and is hereby approved unless revoked for cause.

This letter or the letterhead copy may not be reproduced for use in labeling or advertising, but copies of this letter may be used within your organization and shown as evidence of approval.

CONDITIONS OF APPROVAL:

- 1. An approved Spill-Resistant Pressure-Type Backflow Prevention Assembly shall be installed on the water supply line to each unit, This assembly shall be installed at an elevation 6 inches above the overflow rim of the tub, OR An approved Reduced-Pressure Principle Backflow Prevention Assembly (RP) shall be installed on each of the hot and cold water supply lines serving multiple units per Table 6-2 and Section 94.603 of the LAPC, 2017 Edition.**
- 2. Drain line shall be routed without dips or sags to terminate 1" or two-pipe sizes, whichever is greater, above the flood level rim of an approved indirect waste receptor per Section 94.801 of LAPC, 2017 Edition.**

Each item shall have the name or trademark of manufacturer and model number where it will be visible for inspection.

In order to renew this approval, an application and reexamination fee must be submitted on or before the expiration date shown above. Arrangement shall be made to remove any test samples remaining in the Laboratory. Samples remaining after 21 days from the date of this notice will be shipped collect by the most convenient carrier or disposed of in accordance with applicable regulation.

William J Miranda
Mechanical Testing Laboratory, Test Engineer

**Forever Stainless Steel
M-110099
Stainless Steel Petwash Tubs**

List of Approved Models

A48	Z60HTP	W60HTP
A48HT	ZR60	C60HTY
AR48	ZR60HTY	C60HTY-ADA
AR48HT	ZR60HTP	N60HTY
A52HTY	W48	N60HTY-ADA
A52HTP	W48HT	PCM1000
ADA60HTY	W52HTY	PCM2000
AR52HTY	W52HTP	PCM3000
AR52HTP	W60	PCM4000
Z60	W60HTY	
Z60HTY		

Explanation of designations:

The numbers (48, 52, or 60) indicate the length of tub (end-to-end) in inches.

A models are 24" wide (front-to-back).

Z models are 27" wide (front-to-back).

R models have a door and built-in retractable ramp.

W, C, and N models have a door but no ramp.

HT models have a built-in hair catching system 4 inches wide.

HTY models have a built-in hair catching system 8 inches wide.

HTP models have a built-in hair catching system 8 inches wide and a container for a bathing pump.

C and N models do not have a surround.

N models are walk-around tubs with a door on one end.

ADA indicates compliance with Americans with Disabilities Act.

PCM models are shallow in depth (7" or 14" vs. 16" or 20" for other models).