

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

VAN AMBATIELOS
PRESIDENT

E. FELICIA BRANNON
VICE PRESIDENT

JOSELYN GEAGA-ROSENTHAL
GEORGE HOVAGUIMIAN
JAVIER NUNEZ

JOE SUAREZ
INTERNATIONAL CARBONIC INC
16630 KOALA ROAD
ADELANTO, CA 92301

Telephone: 760-246-3900

Models:

See the Attached List of Models

CITY OF LOS ANGELES
CALIFORNIA



ERIC GARCETTI
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

FRANK M. BUSH
GENERAL MANAGER
SUPERINTENDENT OF BUILDING

OSAMA YOUNAN, P.E.
EXECUTIVE OFFICER

File Number: M-860168

Effective Date: 11/30/2017

Expiration Date: 10/01/2018

Manufacturer: INTERNATIONAL CARBONIC
INC

Item: DISPENSER, BEVERAGE

PLEASE REFER TO THE APPLICATION NUMBER ON ALL CORRESPONDENCE, PHONE CALLS & SAMPLES

The item processed under the above file number has been tested, examined and found to comply with applicable Los Angeles Plumbing Code (LAPC) and/or Los Angeles Mechanical Code (LAMC) and is hereby approved unless revoked for cause.

This letter or the letterhead copy may not be reproduced for use in labeling or advertising, but copies of this letter may be used within your organization and shown as evidence of approval.

CONDITIONS OF APPROVAL:

- 1. An approved vented backflow preventer shall be installed on each potable water supply to the carbonator and to the beverage dispenser per Section 94.603.5.12 of LAPC, 2017 Edition.**
- 2. For non-carbonated dispensers, an approved double check valve shall be installed on each water inlet per Section 94.603.0 of LAPC, 2017 Edition.**
- 3. Drain line shall be routed without dips or sags to terminate 1" or two-pipe size, whichever is greater, above the flood level rim of an approved indirect waste receptor per Section 94.801.0 of LAPC, 2017 Edition.**

Each item shall have the name or trademark of manufacturer and model number where it will be visible for inspection.

In order to renew this approval, an application and reexamination fee must be submitted on or before the expiration date shown above. Arrangement shall be made to remove any test samples remaining in the Laboratory. Samples remaining after 21 days from the date of this notice will be shipped collect by the most convenient carrier or disposed of in accordance with applicable regulation.

William J Miranda
Mechanical Testing Laboratory, Test Engineer

M-860168: INTERNATIONAL CARBONIC INC.**DISPENSER, BEVERAGE****APPROVED MODELS**

CARBONATORS: SF(-II, -W-II4W)

LIL FELLA SERIES: LF(-12, -23, -R, -J), LF-MS (J, PRE-C, R, H-J-R, -J-SS-PP-SC, -J-PP)

SPACE CADET SERIES: SC(-BF, -R, -BF-J), RC-SCR, VSC-II

TOPPER SERIES: TOPPER (-J, -II-J, -II, -PREMIX)

CUBE SERIES: CUBE, (-UC, -R, -PRE, -J, -CWD, -UCM)

LE MONSTRE SERIES: LM

ICE COOLED SYSTEMS: 242239, 152217, 222021, I.C.I., 232321

PREMIER 2000 SERIES: P-2000 (-J, -PRE, -R)

PREMIER-JR SERIES: P-JR (-CWD, -CWD-UD, -CWD-PB, -PRE)

CONCEPT 6000 SERIES: CONCEPT 6000, CONCEPT 6000-J, CONCEPT 6000-J-PP-SS

TOWER MAX SERIES: TM-10, TM-20(R), TM-30(R), TM-40(R) TM-50, TM-60

CONCEPT JUNIOR SERIES: C-JR-J, C-JR-PP

- x -