

CITY OF LOS ANGELES
CALIFORNIA

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

VAN AMBATIELOS

PRESIDENT

E. FELICIA BRANNON

VICE-PRESIDENT

JOSELYN GEAGA-ROSENTHAL

GEORGE HOVAGUIMIAN

JAVIER NUNEZ



ERIC GARCETTI

MAYOR

DEPARTMENT OF
BUILDING AND SAFETY

201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

RAYMOND S. CHAN, C.E., S.E.

GENERAL MANAGER

FRANK BUSH

Executive Officer

OUE - US Bank Tower
633 W. 5th St., 8th Floor
Los Angeles, CA 90071
Attn: Lucy Rumantir

Electrical Testing Laboratory

2319 Dorris Place, Los Angeles, CA 90031
(323) 224-2168

www.LADBS.org

Approved Date: June 3, 2016
Application No.: 500795
Name of Item: Interactive Infinity Mirror & Lighting
Manufacturer: Cinnabar
Model: Infinity Mirror
Serial No.: OUE-A
Location: OUE - US Bank Tower - 54th Floor
633 W. 5th St., Los Angeles, 90071

Conditions of Approval:

1. Not Suitable for Hazardous / Classified Areas.
2. This equipment shall only be used in dry locations.
3. This device shall only be installed and maintained by authorized, trained and qualified personnel.
4. The final installation of this system shall comply with all the local and national codes.
5. This device is only evaluated for fire and shock hazard, its performance and accuracy have not been investigated.

The equipment processed under the above application number has been evaluated and found to comply with the applicable requirements of the Los Angeles City Electrical Code and is hereby accepted. The approval of this equipment is only valid while installed and maintained in accordance with all the related codes, standards and the manufacturer's installations and operating instructions. This equipment shall not be relocated or modified without prior authorization from Electrical Testing Lab.

This acceptance is neither a product endorsement nor a certification of accuracy, function or calibration of the equipment. This acceptance does not fulfill the requirements of approval which may be required under the Plumbing or Mechanical Codes of the City of Los Angeles.

The enclosed label(s) 1 total, No(s) AA053505 shall be affixed adjacent to the nameplate of the equipment where it will be accessible for inspection. No label may be affixed to any equipment not currently accepted by the Department of Building and Safety.

NOTE: This acceptance applies only to the actual equipment examined at the above field location and is not subject to annual re-examination.

Behrooz Hooriani, P.E.
Electrical Engineer
Electrical Testing Laboratory
2319 Dorris Place
Los Angeles, CA 90031
(323) 224-2168 Tel
(323) 224-2161 Fax
www.LADBS.org

