

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

VAN AMBATIELOS
PRESIDENT

E. FELICIA BRANNON
VICE PRESIDENT

JOSELYN GEAGA-ROSENTHAL
GEORGE HOVAGUIMIAN
JAVIER NUNEZ

CITY OF LOS ANGELES
CALIFORNIA



ERIC GARCETTI
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

RAYMOND S. CHAN, C.E., S.E.
GENERAL MANAGER

FRANK BUSH
EXECUTIVE OFFICER

Michael Saveliev
SHURFLO
3545 Harbor Gateway South, Suite 103
Costa Mesa, CA 92626

Telephone: 800-854-3218

Models:

804: -023, 023-SV, -037, -037-SV, -026 | WB2-LVPO: -01, -02 | WB2-M3-22: -001, -002, -004 | WB6-M3-22: -001, -002, -003.

File Number: M-090062

Effective Date: 04/20/2015

Expiration Date: 05/01/2016

Manufacturer: SAME

Item: WATER BOOSTER FILTRATION
SYSTEMS

PLEASE REFER TO THE APPLICATION NUMBER ON ALL CORRESPONDENCE, PHONE CALLS & SAMPLES

The item processed under the above file number has been tested, examined and found to comply with applicable Los Angeles Plumbing Code (LAPC) and/or Los Angeles Mechanical Code (LAMC) and is hereby approved unless revoked for cause.

This letter or the letterhead copy may not be reproduced for use in labeling or advertising, but copies of this letter may be used within your organization and shown as evidence of approval.

CONDITIONS OF APPROVAL:

- 1. Potable water supply inlet of this product shall be protected by a City of Los Angeles approved reduced pressure principle backflow preventer per Section 94.603.0 of LAPC, 2014 Edition.**
- 2. Drain line shall be routed without dips or sags to terminate 1" or two-pipe size, whichever is greater, above the flood level rim of an approved indirect waste receptor per Section 94.801.0 of LAPC, 2014 Edition.**
- 3. Electrical components shall be tested and listed by a City of Los Angeles recognized listing and testing agency, or shall be tested and approved by the City of Los Angeles Electrical Testing Laboratory.**

Each item shall have the name or trademark of manufacturer and model number where it will be visible for inspection.

In order to renew this approval, an application and reexamination fee must be submitted on or before the expiration date shown above. Arrangement shall be made to remove any test samples remaining in the Laboratory. Samples remaining after 21 days from the date of this notice will be shipped collect by the most convenient carrier or disposed of in accordance with applicable regulation.

Manuel Hernandez
Mechanical Testing Laboratory, Test Engineer