

**BOARD OF
BUILDING AND SAFETY
COMMISSIONERS**

JAVIER NUÑEZ
PRESIDENT

MARSHA L. BROWN
VICE-PRESIDENT

VAN AMBATIELOS

PEDRO BIRBA

ELENORE A. WILLIAMS

CITY OF LOS ANGELES
CALIFORNIA



ANTONIO R. VILLARAIGOSA
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

ANDREW A. ADELMAN, P.E.
GENERAL MANAGER

RAYMOND CHAN
EXECUTIVE OFFICER

Decra Roofing Systems, Inc.
1230 Railroad St.
Corona, CA 92882

RESEARCH REPORT: RR 25463
(CSI # 07410)

Attn: David Elorede
(951) 272-8180 ext. 1152

BASED UPON ICBO ES EVALUATION
REPORT NO. ESR-1483

REEVALUATION DUE DATE:
November 1, 2008

GENERAL APPROVAL - Reevaluation - Decra Shingle Steel Roofing Panels

DETAILS

The above assemblies and/or products are approved when in compliance with the description, use, identification and findings of Report No.ESR-1483, dated January 1, 2006, of the ICC Evaluation Service, Incorporated. The report, in its entirety, is attached and made part of this general approval.

The part of Report No. ESR-1483 marked by the asterisk is modified by the Los Angeles Building Department from this approval.

Conditions of Approval:

1. The roof covering shall not be installed over existing wood shakes or wood shingles per Section 91.1514 of the 2002 Los Angeles City Building Code.
2. Except as specified herein, installations of the tiles shall be in accordance with the manufacturer's instructions.
3. The installation of these panels must comply with Information Bulletin P/BC 2001-16 "Dwellings in High Wind Velocity Areas".
4. For all new construction, including additions, the roof panel shall be installed over minimum 15/32" plywood.

RR 25463
Page 1 of 2

Tasman Roofing Inc.
RE: Decra Shingle Steel Roofing Panels

5. Reroofing applications shall comply with Section 4.3 of ICC ERS-1483 and Section 91.1507 and 91.1516 of the 2002 Los Angeles City Building Code.
6. Underlayment for Class A assemblies shall be installed as follows:
 - (1) One layer of Type G3 cap sheet (72# cap sheet).
 - (2) For 15/32" plywood or spaced sheathing, add one layer of ELK Versa Shield over 30 lb felt (see LARR 25424, System).

DISCUSSION

The clerical modification is to change the contact person and telephone number.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this approval have been met in the project in which it is to be used.

This general approval will remain effective provided the Evaluation report is maintained valid and unrevised with the issuing organization. Any revisions to the report must be submitted to this Department, with appropriate fee, for review in order to continue the approval of the revised report.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

YEUAN CHOU, Chief
Engineering Research Section
2319 Dorris Place
Los Angeles, Ca 90031
Phone (213) 485-2376
Fax (213) 847-0985

RB:elcm
RR25463/wp8.0
R10/13/06
4C/1504

Attachment: ICC ES Evaluation Report No.ESR-1483 (5 pages)

RR 25463
Page 2 of 2