

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

HELENA JUBANY
PRESIDENT

VAN AMBATIELOS
VICE-PRESIDENT

E. FELICIA BRANNON
VICTOR H. CUEVAS
SEPAND SAMZADEH

CITY OF LOS ANGELES
CALIFORNIA



ANTONIO R. VILLARAIGOSA
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

RAYMOND S. CHAN, C.E., S.E.
SUPERINTENDENT OF BUILDING
INTERIM GENERAL MANAGER

May 28, 2013

Attn: *Jeff Edmiston*
Paul Nelson
Pam Pacific Plumbing & Mechanical
7600 World Way West
Los Angeles, CA 90045

Electrical Testing Laboratory
2319 Dorris Place, Los Angeles, CA 90031
(323) 224-2168
www.LADBS.org

Approved Date: May 28, 2013
Application No. 500463
Name of Item: Heat Exchanger
Manufacturer: RECO USA
Model: HXV150-C-14048-DELW
Location: LAX (International Terminal)
380 World Way West
Los Angeles, CA 90045

Conditions of Approval:

1. This equipment shall only be installed and maintained by authorized, trained personnel.
2. The final installation of this system shall comply with all the local and national codes.
3. This system is only evaluated for fire and shock hazard, its performance and accuracy have not been investigated.

The equipment processed under the above application number has been evaluated and found to comply with the applicable requirements of the Los Angeles City Electrical Code and is hereby accepted. The approval of this equipment is only valid while installed and maintained in accordance with all the related codes, standards and the manufacturer's installations and operating instructions. This equipment shall not be relocated or modified without prior authorization from Electrical Testing Lab.

This acceptance is neither a product endorsement nor a certification of accuracy, function or calibration of the equipment. This acceptance does not fulfill the requirements of approval which may be required under the Plumbing or Mechanical Codes of the City of Los Angeles.

Label No(s). AA010047 - AA010050 have been affixed to the equipment at the above location. No label may be affixed to any equipment not currently accepted by the Department of Building and Safety.

NOTE: This acceptance applies only to the actual equipment examined at the above field location and is not subject to annual re-examination.


Nabil Maalouf
Electrical Engineer
Electrical Testing Laboratory
2319 Dorris Place
Los Angeles, CA 90031
(323) 224-2168 Tel
(323) 224-2161 Fax
www.LADBS.org