

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

VAN AMBATIELOS
PRESIDENT

E. FELICIA BRANNON
VICE-PRESIDENT

JOSELYN GEAGA-ROSENTHAL
GEORGE HOVAGUIMIAN
JAVIER NUNEZ

CITY OF LOS ANGELES

CALIFORNIA



ERIC GARCETTI
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

FRANK BUSH
GENERAL MANAGER
SUPERINTENDENT OF BUILDING

OSAMA YOUNAN, P.E.
EXECUTIVE OFFICER

Tim M. Siahatgar/
MHS Building Systems
P.O. Box 51478
Irvine, CA 92619

Attn: Tim Siahatgar
(949) 735-7392
ussystems@aol.com
Office@modularhousingsystems.com

RESEARCH REPORT: RR 25703
(CSI # 06 12 00)

Expires: August 1, 2018
Issued Date: August 1, 2017
Code: 2017 LABC

GENERAL APPROVAL – Initial Approval – MHS Structural Insulated Panel Frame Assembly for Wall, Roof and Floor Panels

DETAILS

MHS Structural Insulated Panel Frame Assembly consists of prefabricated MHS Modular aluminum frame extrusions in conjunction with structural insulated panels (SIP) with EPS foam plastic core material.

All structural insulated panel (SIP) with EPS foam cores to be used with the MHS aluminum frames shall have a valid LARR, ICC or IAPMO listing number.

The aluminum frame is made of MHS aluminum extrusion 170-4W with a base material of 6061-T6 per ASTM B-221. The structural insulated panels consist of oriented strand board (OSB) laminated with structural adhesives. The adhesive shall be a Type II, Class 2, laminating adhesive complying with the ICC-ES Acceptance Criteria for Sandwich Panel Adhesives (AC05).

The EPS foam core shall have a flame spread index not exceeding 25 and a smoke density index not exceeding 450.

RR 25703
Page 1 of 3

This approval is subject to the following conditions:

1. Complete plans and calculations bearing the signature of a licensed civil or structural engineer, registered in the State of California and shall be submitted to the Structural Plan Check Section for review and approval.
2. The panel and frame assembly shall be installed in buildings of Type V construction only.
3. For exterior and applications, panels shall be separated from the building interior with ½” gypsum board or a thermal barrier complying with Section 2603.4 of the 2017 Los Angeles Building Code.
4. Exterior walls must be protected by a water-resistive barrier complying with Section 1404.2 of the 2017 Los Angeles Building Code and by wall coverings that provide the necessary structural resistance to wind and seismic forces in spanning between wall framing members.
5. The fire-resistive rating of the panels as building elements has not been reviewed and is outside the scope of this general approval.
6. The allowable loads are noted in attached tables. The allowable panel capacities shall not be increased for wind and seismic loads.
7. The fabrication of the panels shall be in a shop of a fabricator licensed by the City of Los Angeles Department of Building and Safety in accordance with the manufacturing standards submitted to the Department.
8. Connections of the panel to the building substrate shall be per the attached connection details. The location of the panel connections must be shown and detailed on construction plans reviewed and approved by the Department.
9. The panels shall be installed per the manufacturer published installation instructions. A copy of these instructions shall be available at the construction site.
10. The MHS framing member and connectors shall be labeled with the manufacturer name (MHS Building Systems Co.) and the Los Angeles Research Report number (LARR-25703)

MHS Building Systems
RE: MHS Structural Insulated Panel Frame Assemblies

DISCUSSION

The report is in compliance with 2017 Los Angeles Building Code.

The approval is based on tests on file with the Building Research Section.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this approval have been met in the project in which it is to be used.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

QUAN NGHIEM, Chief
Engineering Research Section
201 N. Figueroa St., Room 880
Los Angeles, CA 90012
Phone - 213-202-9816
Fax - 213-202-9943

EB
RR25703
TLB1700059
R03/28/17
6207

Attachment: Allowable Load Tables (19 pages)
 Connection Details (8 pages)