

CITY OF LOS ANGELES  
CALIFORNIA

BOARD OF  
BUILDING AND SAFETY  
COMMISSIONERS

VAN AMBATIOLOS  
PRESIDENT

E. FELICIA BRANNON  
VICE PRESIDENT

JOSELYN GEAGA-ROSENTHAL  
GEORGE HOVAGUIMIAN  
JAVIER NUNEZ



ERIC GARCETTI  
MAYOR

DEPARTMENT OF  
BUILDING AND SAFETY  
201 NORTH FIGUEROA STREET  
LOS ANGELES, CA 90012

FRANK M. BUSH  
GENERAL MANAGER

OSAMA YOUNAN, P.E.  
EXECUTIVE OFFICER

**WET**

10847 Sherman Way  
Sun Valley, CA 91352  
Attn: Maria Villamil

**Electrical Testing Laboratory**  
2319 Dorris Place, Los Angeles, CA 90031  
(323) 224-2168  
[www.LADBS.org](http://www.LADBS.org)

Approved Date:	October 20, 2016
Application No.:	500812
Name of Item:	CNC Machine
Manufacturer:	Makino
Model:	EDAF3
Serial No.:	E080496
Location:	<i>WET</i> 10847 Sherman Way, Sun Valley, 91352

**Conditions of Approval:**

1. Not Suitable for Hazardous / Classified Areas.
2. This equipment shall only be used in dry locations.
3. This device shall only be installed, maintained and operated by authorized, trained and qualified personnel.
4. The final installation of this system shall comply with all the local and national codes.
5. This device is only evaluated for fire and shock hazard, its performance and accuracy have not been investigated.

The equipment processed under the above application number has been evaluated and found to comply with the applicable requirements of the Los Angeles City Electrical Code and is hereby accepted. The approval of this equipment is only valid while installed and maintained in accordance with all the related codes, standards and the manufacturer's installations and operating instructions. This equipment shall not be relocated or modified without prior authorization from Electrical Testing Lab.

This acceptance is neither a product endorsement nor a certification of accuracy, function or calibration of the equipment. This acceptance does not fulfill the requirements of approval which may be required under the Plumbing or Mechanical Codes of the City of Los Angeles.

The enclosed label(s) 1 total, No(s) AA053601 shall be affixed adjacent to the nameplate of the equipment where it will be accessible for inspection. No label may be affixed to any equipment not currently accepted by the Department of Building and Safety.

NOTE: This acceptance applies only to the actual equipment examined at the above field location and is not subject to annual re-examination.

**Behrooz Hooriani, P.E.**  
Electrical Engineer  
Electrical Testing Laboratory  
2319 Dorris Place  
Los Angeles, CA 90031  
(323) 224-2168 Tel  
(323) 224-2161 Fax  
[www.LADBS.org](http://www.LADBS.org)

