

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

MARSHA L. BROWN
PRESIDENT

VAN AMBATIELOS
VICE-PRESIDENT

VICTOR H. CUEVAS
HELENA JUBANY
ELENORE A. WILLIAMS

CITY OF LOS ANGELES

CALIFORNIA



ANTONIO R. VILLARAIGOSA
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

ROBERT R. "BUD" OVROM
GENERAL MANAGER

RAYMOND S. CHAN, P.E., S.E.
EXECUTIVE OFFICER

Earthbound Corporation
17361 Tye Street, SE
Monroe, WA 98272

Attn: Edward Chin, P. E.
(360) 863-0722

RESEARCH REPORT: RR 25404
(CSI # 06060)

BASED UPON ICC ES EVALUATION
REPORT NO. ESR-2848

REEVALUATION DUE DATE:

May 1, 2011

Issued Date: June 1, 2010

Code: 2008 LABC

GENERAL APPROVAL – Revaluation- The Earthbound Seismic Holdown System using SlackJack Compensating Device for Shear Walls.

DETAILS

The above assemblies and/or products are approved when in compliance with the description, use, identification and findings of Evaluation Report No.ESR-2848, dated June 1, 2009, revised March 2010 of the ICC Evaluation Service, Incorporated. The report, in its entirety, is attached and made part of this general approval.

The parts of Report No.ESR-2848 which are excluded on the attached copy have been removed by the Los Angeles City Building Department as not being included in this approval.

The approval is subject to the following conditions:

1. Each SlackJack ® shrinkage compensating device bears a label with the evaluation report holder name (Earthbound) and web address, the product name (SlackJack ®), and the evaluation report number (ESR-2848). The devices are color-coded, as indicated in Table 1, to identify the specific model and series number. Each SlackJack ® shrinkage compensating device is individually packaged, along with the color-coded swivel washer and the hex nut.
2. Installation of the holdown system shall be in accordance with the manufacturer's instructions.

RR 25404
Page 1 of 3

Earthbound Corporation

Re: Earthbound Seismic Holdown System using SlackJack Compensating Device for Shear Walls

3. The Earthbound System can be used to resist the tension force induced by wind or seismic loads.
4. The allowable load values shall not be further increased for short duration loading, such as wind and seismic.
5. Complete design calculations shall be submitted to the Structural Plan Check for each tie-down system installation. Plans and calculations shall bear the stamp and signature of a California registered civil or structural engineer. Calculations must consider:
 - a. the rod value of 0.2" elongation between connectors/restraints.
 - b. bearing plate value per Code, consider wood bearing capacity of the net area and plate bending.
 - c. wood post shall be designed for combined stresses at the critical net section and for compression parallel and perpendicular to grain.
 - d. The Code allowable value of anchor bolt and tension rod.

Earthbound Corporation

Re: Earthbound Seismic Holdown System using SlackJack Compensating Device for Shear Walls

DISCUSSION

The report is in compliance with 2008 LABC.

The approval is based on test and analyses.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this approval have been met in the project in which it is to be used.

This general approval will remain effective provided the Evaluation Report is maintained valid and unrevised with the issuing organization. Any revisions to the report must be submitted to this Department, with appropriate fee, for review in order to continue the approval of the revised report.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using item approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

WILLIAM STUTSMAN, Chief
Engineering Research Section
201 N. Figueroa St., Room 8801
Los Angeles, CA 90012
Phone – 213-202-9812
Fax – 213-202-9943

WS:ws
RR25404/msw7
R05/27/2010
5D2/2306.5

Attachment: ICC ES Evaluation No. ESR-2848 (4pages)