

CITY OF LOS ANGELES  
CALIFORNIA

BOARD OF  
BUILDING AND SAFETY  
COMMISSIONERS

VAN AMBATIELOS  
PRESIDENT

E. FELICIA BRANNON  
VICE PRESIDENT

JOSELYN GEAGA-ROSENTHAL  
GEORGE HOVAGUIMIAN  
JAVIER NUNEZ



ERIC GARCETTI  
MAYOR

DEPARTMENT OF  
BUILDING AND SAFETY  
201 NORTH FIGUEROA STREET  
LOS ANGELES, CA 90012

FRANK M. BUSH  
GENERAL MANAGER  
SUPERINTENDENT OF BUILDING

OSAMA YOUNAN, P.E.  
EXECUTIVE OFFICER

Pacific Woodtech Corporation  
1850 Park Lane  
Burlington, WA 98233

Attn: Dawn Greenwood  
(360) 707-2200

RESEARCH REPORT: RR 25448  
(CSI # 06 17 13)

BASED UPON ICC EVALUATION SERVICE  
REPORT NO. ESR-2909

REEVALUATION DUE  
DATE: November 1, 2020  
Issued Date: December 1, 2018  
Code: 2017 LABC

**GENERAL APPROVAL** – Reevaluation and Clerical Modification - Pacific Woodtech Laminated Veneer Lumber (LVL).

**DETAILS**

The above assemblies and/or products are approved when in compliance with the use, description, design, installation, conditions of use, and identification of Evaluation Report No. ESR-2909 reissued September 1, 2017, revised April 2018 of the ICC-ES Evaluation Services, LLC. The report, in its entirety, is attached and made part of this general approval.

The part of Report No.ESR-2909 marked by the asterisk is modified by the Los Angeles Building Department from this approval.

**The approval is subject to the following conditions:**

1. All stress adjustment factors specified in Table 8.3.1 of NDS 2012 shall apply to LVL.
2. Fabrication of LVL shall be done in the shop of a Los Angeles City licensed fabricator and shall be in accordance with Chapter 23 of the 2017 Los Angeles City Building Code.
3. LVL is limited to end-use locations at which the moisture content is equal to or less than 16 percent.

RR 25448  
Page 1 of 3

Pacific Woodtech Corporation

RE: Pacific Woodtech Laminated Veneer Lumber (LVL).

4. For repetitive members, an increase of four percent in allowable bending stresses is permitted.
5. Qualified adhesives, veneer species and veneer grades are as specified in the approved quality control manual.
6. Pacific Woodtech® LVL is identified by a stamp noting the manufacturer's name (Pacific Woodtech), product trade name, grade, product date, evaluation report number (ESR-2902), qualified inspection agency name or logo (APA), and manufacturer's APA mill number (1047).

## DISCUSSION

The technical modification is to update the report to the 2017 Los Angeles City Building Code and to update the contact person.

The report is in compliance with the 2017 Los Angeles City Building Code.

The approval is based on tests in accordance with ICC-ES Accepted Criteria for Structural Wood-based Products (AC 47), dated June 2018 and for Rim Board Products (AC124), dated October 2016.

This general approval will remain effective provided the Evaluation Report is maintained valid and unrevised with the issuing organization. Any revisions to the report must be submitted to this Department, with appropriate fee, for review in order to continue the approval of the revised report.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

Pacific Woodtech Corporation

RE: Pacific Woodtech Laminated Veneer Lumber (LVL).

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this Approval have been met in the project in which it is to be used.

---

DAVID CHANG, Chief  
Engineering Research Section  
201 N. Figueroa St., Room 880  
Los Angeles, CA 90012  
Phone- 213-202-9812  
Fax- 213-202-9943

DE  
RR25448  
TLB1800308  
R12/14/18  
2304.9

Attachment: ICC ES Report No. ESR-2909 (4 Pages)