

CITY OF LOS ANGELES
CALIFORNIA

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

VAN AMBATIELOS
PRESIDENT

E. FELICIA BRANNON
VICE PRESIDENT

JOSELYN GEAGA-ROSENTHAL
GEORGE HOVAGUIMIAN
JAVIER NUNEZ



ERIC GARCETTI
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

FRANK M. BUSH
GENERAL MANAGER
SUPERINTENDENT OF BUILDING

OSAMA YOUNAN, P.E.
EXECUTIVE OFFICER

Sanjay Shah
Advanced Aquaduck Systems
6481 Box Springs Blvd
Riverside, CA 92507

Telephone: 951-697-1140

Models:

APD48165D, APD72165D | Outlet options: 4", 5" and 6"

File Number: M-080124

Effective Date: 07/01/2019

Expiration Date: 07/01/2020

Manufacturer: ADVANCED AQUADUCK
SYSTEMS

Item: TRENCH DRAIN

PLEASE REFER TO THE APPLICATION NUMBER ON ALL CORRESPONDENCE, PHONE CALLS & SAMPLES

The item processed under the above file number has been tested, examined and found to comply with applicable Los Angeles Plumbing Code (LAPC) and/or Los Angeles Mechanical Code (LAMC) and is hereby approved unless revoked for cause.

This letter or the letterhead copy may not be reproduced for use in labeling or advertising, but copies of this letter may be used within your organization and shown as evidence of approval.

CONDITIONS OF APPROVAL:

See attached Conditions of Approval.

Each item shall have the name or trademark of manufacturer and model number where it will be visible for inspection.

In order to renew this approval, an application and reexamination fee must be submitted on or before the expiration date shown above. Arrangement shall be made to remove any test samples remaining in the Laboratory. Samples remaining after 21 days from the date of this notice will be shipped collect by the most convenient carrier or disposed of in accordance with applicable regulation.

Irene M Pool Tamayo
Mechanical Testing Laboratory, Test Engineer

**Advanced Aquaduck Systems
M-080124**

Trench Drain

Conditions of Approval:

1. This product may be used in residential or commercial installations.
2. The product shall be covered with approved grates as recommended by the manufacturer.
3. All joints and connections shall be watertight and ground to provide a smooth transition.
4. All components shall be anchored to and surrounded by a minimum of four inches of continuous concrete beneath and on all sides.
5. These drain systems shall not be installed under any fixed equipment unless the bottom of such equipment is at least 12 inches above the floor surface and will not restrict access to the trench for clean out purposes.
6. These drain systems shall be installed per manufacturer's printed installation instructions.
7. This product shall be permanently identified with the manufacturer's name and appropriate model number where visible for inspection purposes.