

BOARD OF  
BUILDING AND SAFETY  
COMMISSIONERS

VAN AMBATIELOS  
PRESIDENT  
E. FELICIA BRANNON  
VICE-PRESIDENT

JOSELYN GEAGA-ROSENTHAL  
GEORGE HOVAGUIMIAN  
JAVIER NUNEZ

CITY OF LOS ANGELES  
CALIFORNIA



ERIC GARCETTI  
MAYOR

DEPARTMENT OF  
BUILDING AND SAFETY  
201 NORTH FIGUEROA STREET  
LOS ANGELES, CA 90012

FRANK M. BUSH  
GENERAL MANAGER  
SUPERINTENDENT OF BUILDING

OSAMA YOUNAN, P.E.  
EXECUTIVE OFFICER

**R.A. Fischer, Co.**  
9428 Eton Ave., Suite# N  
Chatsworth, CA 91311  
Attn: Jennifer Jacobellis

**Electrical Testing Laboratory**

201 N. Figueroa, #500, Los Angeles, CA 90012

(213) 482-6721 [www.LADBS.org](http://www.LADBS.org)

Approved:	January 5, 2018
Expiration:	January 5, 2019
Application No:	500053
Name of Item:	Galvanic Unit
Manufacturer:	R.A. Fischer, Inc.
Model:	MD-2

**Conditions of Approval:**

1. Not Suitable for Hazardous / Classified Areas.
2. This device shall only be used by trained and qualified medical personnel.
3. This device shall only be maintained by authorized and trained personnel.
4. This equipment shall only be used indoor in dry locations.
5. The final installation of this device shall comply with all the local and national codes.
6. This device is only evaluated for fire and shock hazard, its performance and accuracy have not been investigated.

The above mentioned item has been examined and found to be in substantial compliance with the standards established for such equipment. This approval shall expire on the date indicated unless revoked sooner for cause.

Each approved item shall bear the approval label of the Department, attached in a manner determined by the standards, or otherwise made readily visible for inspection without disassembly. Approval labels may be obtained only by the written authorization of the applicant or his authorized representative and shall be available only during the year of approval. The applicant shall be held responsible for this use. No labels shall be affixed to any item not currently approved by the Department, nor shall the labels be transferred to the possession of any unauthorized person.

Prior to the expiration date of an approval, the applicant shall file the following in order to initiate renewal processing: (1)A completed set of application forms; (2)The required renewal application fee and any supplemental fees if required; and (3)A current sample of the article submitted for approval renewal produced within 90 days of submittal date. Failure to submit any of the foregoing by the expiration date will result in closing of the file.

This approval does not fulfil the requirements for approval which may be required under the Plumbing or Mechanical Code of the City of Los Angeles.

**Behrooz Hooriani, P.E.**

Electrical Engineer

**Electrical Testing Laboratory**

201 N. Figueroa St., Suite #500

Los Angeles, CA 90012

(213) 482-0045 Tel

(213) 482-6554 Fax

[www.LADBS.org](http://www.LADBS.org)

