

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

MARSHA L. BROWN
PRESIDENT

VAN AMBATIELOS
VICE-PRESIDENT

VICTOR H. CUEVAS
HELENA JUBANY
ELENORE A. WILLIAMS

CITY OF LOS ANGELES

CALIFORNIA



ANTONIO R. VILLARAIGOSA
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

ROBERT R. "BUD" OVROM
GENERAL MANAGER

RAYMOND S. CHAN, P.E., S.E.
EXECUTIVE OFFICER

MMFX Technologies Corporation
2415 Campus Drive, Suite 100
Irvine, CA 92612

Attn: Johnny Kwok, S.E. MBA
(949) 476-7600

RESEARCH REPORT: RR 25598
(CSI #03200)

Expires: January 1, 2013
Date Issued: February 1, 2011
Code: 2011 LABC

GENERAL APPROVAL – Renewal - MMFX deformed steel bars for use in the design of reinforced concrete mat and spread foundation systems using up to 100,000 psi yield strength.

DETAILS

MMFX deformed steel bars conform to ASTM A1035 specification as follows:

Mechanical Properties:

Steel Grade	Grade 100	Grade 120
Tensile strength, min. psi	150,000	150,000
Yield strength (0.2% offset), min. psi	100,000	120,000
Stress corresponding to an extension under load of 0.0035 in/in, min. psi	80,000	90,000
Elongation in 8 in min. %:		
#3 through #11	7	7
# 14, #18	6	---

Chemical Properties:

Steel Type Element	Type CS (High Cr) max.^a	Type CL (Low Cr) max.^a
Carbon	0.15%	0.17%
Chromium	8.0 to 10.9%	4.0 to 6.0%
Manganese	1.5%	1.5%
Nitrogen	0.05%	0.05%
Phosphorus	0.035%	0.035%
Sulfur	0.045%	0.045%
Silicon	0.50%	0.50%

^aMaximum unless range is indicated. Percentages refer to weight percentages

RR 25598
Page 1 of 3

MMFX Technologies Corporation
RE: MMFX deformed steel bars

Product name shall be specified in accordance to the following naming system, with Type (CS or CL) followed by Grade (100 or 120):

- MMFX CS100
- MMFX CS120
- MMFX CL100
- MMFX CL120

The approval is subject to the following conditions:

1. MMFX deformed steel bars may be used for design of reinforced concrete mat and spread foundation systems based on the following yield strength:
Tension: 100,000 psi. Compression: 80,000 psi.
2. MMFX deformed steel bars, when designed using higher yield strength, shall have proportionally longer development length and lap length based on 60,000 psi yield strength prescribed in 2011 Los Angeles City Building Code.
3. Test data from the mill or from a Los Angeles City approved testing agency shall verify the material in accordance with the above modified specifications for each job.
4. MMFX deformed steel bars shall be distinctly marked for field identification
5. All steel materials shall be identified as – “LARR 25598” on bar tags.
6. Mechanical couplers to develop full strength require a separate approval.
7. MMFX deformed steel bars shall not be welded, unless the welding protocol is provided by manufacture for specific applications and approved with an LARR.

MMFX Technologies Corporation
RE: MMFX deformed steel bars

DISCUSSION

The report is in compliance with the 2011 City of Los Angeles Building Code.

The approval is in accordance with ACI 318-08.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this approval have been met in the project in which it is to be used.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

WILLIAM STUTSMAN, Chief
Engineering Research Section
201 N. Figueroa St, Room 880
Los Angeles, CA 90012
Phone - 213-202-9812
Fax - 213-202-9943

BG:bg
RR25598/MSWord2007
R01/21/2011
3CI/ACI 318 Sec 3.5.3