

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

—
HELENA JUBANY
PRESIDENT

VAN AMBATIELOS
VICE-PRESIDENT

E. FELICIA BRANNON
VICTOR H. CUEVAS
SEPAND SAMZADEH

CITY OF LOS ANGELES

CALIFORNIA



ERIC GARCETTI
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

—
RAYMOND S. CHAN, C.E., S.E.
SUPERINTENDENT OF BUILDING
INTERIM GENERAL MANAGER

ODL Incorporated
215 E. Roosevelt Ave.
Zeeland, MI 49464

Attn. Jim Allardyce
(616) 748 5437

RESEARCH REPORT: RR 24912
(CSI # 08 62 00)

BASED UPON ICC EVALUATION SERVICE
REPORT NO. ESR-1835

REEVALUATION DUE

DATE: January 1, 2016
Issued Date: December 1, 2013
Code: 2011 LABC

GENERAL APPROVAL – Renewal- ODL EZ Tubular Skylights

DETAILS

ODL EZ Tubular Skylights are approved when in compliance with the description, use, identification and findings of Report No. ESR-1835, reissued May 1, 2013 of the ICC Evaluation Service, Incorporated. The report in its entirety is attached and made part of this general approval.

The parts of Report No. ESR-1835 marked by the asterisks have been removed by the Los Angeles Building Department from this approval.

The approval is subject to the following conditions:

1. Approval is limited to Skylight models that shall be installed with fire ring and spun aluminum self-flashing curbs.
2. Skylight installation must comply with Sections 2405.4 and 2610 of the 2011 Los Angeles City Building Code and with the manufacturer's instructions and this report.
3. Skylights are limited to installations on roofs with slopes of max 45 degrees from the horizontal.

RR 24912
Page 1 of 2

4. The allowable positive and negative (inward or outward) loads for the skylights are shown in Table 2 of the attached ICC-ES report.

DISCUSSION

The report is in compliance with the 2011 Los Angeles City Building Code.

The approval was based on tests in accordance with ICC-ES Acceptance Criteria for Plastic Glazed Skylights (AC16), dated April 2011.

The Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this approval have been met in the project in which it is to be used.

ALLEN PEERY, Chief
Engineering Research Section
201 N. Figueroa St., Room 880
Los Angeles, CA 90012
Phone- 213-202-9812
Fax- 213-202-9943

RJG
RR25949/MSWord2010
R11/08/13
7A/2405/2610