

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

MARSHA L. BROWN
PRESIDENT

VAN AMBATIELOS
VICE-PRESIDENT

VICTOR H. CUEVAS
HELENA JUBANY
ELENORE A. WILLIAMS

CITY OF LOS ANGELES

CALIFORNIA



ANTONIO R. VILLARAIGOSA
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

ANDREW A. ADELMAN, P.E.
GENERAL MANAGER

RAYMOND CHAN
EXECUTIVE OFFICER

Mer-Kote/ParexLahabra
501 South Van Ness
Torrance, CA 90501

Attn: Tina Bramlett
(800) 851-6303 X 3286

RESEARCH REPORT: RR 25774
(CSI # 07180)

BASED UPON ICC EVALUATION
REPORT NO. ER-5968

REEVALUATION DUE DATE :
April 1, 2010
Issued Date: April 1, 2009
Code: 2002 LABC

GENERAL APPROVAL – Mer-Ko Shur Deck Roof and Walking Deck System.

DETAILS

The above assemblies and/or products are approved when in compliance with the description, use, identification and findings of Legacy Report No. ER-5968 dated January 1, 2007, of the ICC Evaluation Service, Incorporated. The report, in its entirety, is attached and made part of this general approval.

The approval is subject to the following conditions:

1. For wood framed, type V construction, all reroofing and new construction, including additions, the roof covering shall be installed over a minimum $\frac{5}{8}$ " exterior grade plywood with all edges blocked.
2. Deck slope shall be as specified on the approved plans but not less than $\frac{1}{4}$ " : 1'.
3. Each sack of Shur Deck Compound and each pail of Shur Deck Mastic and Mer-Ko Seal is labeled with product name, the manufacturer's name and address, the evaluation report number (ER-5968), the shelf life, a production report number keyed to the date of manufacture, and the name of inspection agency (Ramtech Laboratories).
4. The system has a class A roof classification over plywood decks.

RR 25774
Page 1 of 2

Mer-Kote/ParexLahabra
RE: Mer-Ko Shur Deck and Walking Deck System

DISCUSSION

The approval is based on tests, in accordance with ICC-ES (AC 39).

The status of the referenced Legacy Report No. ER-5968, dated January 1, 2007, which is currently beyond its re-examination date is still valid. The validity of the evaluation report was verified with ICC.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

This general approval will remain effective provided the Evaluation Report is maintained valid and unrevised with the issuing organization. Any revisions to the report must be submitted to this Department, with appropriate fee, for review in order to continue the approval of the revised report.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this approval have been met in the project in which it is to be used.

YEUAN CHOU, Chief
Engineering Research Section
201 N. Figueroa St., Room 880
Los Angeles, CA 90012
Phone (213) 202-9812
Fax (213) 202-9942

YC:elcm
RR25774/wp8.0
R03/31/09
4C/1501/1504.1

Attachment: ICC ES Legacy Report No. ER-5968 (2 Pages).