

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

MARSHA L. BROWN
PRESIDENT

VAN AMBATIELOS
VICE-PRESIDENT

VICTOR H. CUEVAS
HELENA JUBANY
ELENORE A. WILLIAMS

CITY OF LOS ANGELES
CALIFORNIA



ANTONIO R. VILLARAIGOSA
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

ROBERT R. "BUD" OVROM
GENERAL MANAGER

RAYMOND S. CHAN, P.E., S.E.
EXECUTIVE OFFICER

Pacific Wood Preserving.
1601 New Stine Road, Suite 250
Bakersfield, CA 93309

Attn: Mike Freeman
(901) 754-2116

RESEARCH REPORT: RR 25905
(CSI 06 05 07.13)

BASED UPON ICC EVALUATION
SERVICE REPORT NO. ESR-3038

REEVALUATION DUE

DATE: May 1, 2014

Issued Date: August 1, 2012

Code: 2011 LABC

GENERAL APPROVAL – Reevaluation – PACBOR® Preservative Treated Lumber and Plywood

DETAILS

The above products are approved when in compliance with the description, use identification and findings of Report No. ESR-3038, issued April 1, 2011, revised April 2012, of the ICC Evaluation Service. That report, in its entirety, is attached and made a part of this general approval.

The parts of Report No. ESR-3038 marked by the asterisks are modified by the Los Angeles City Department of Building and Safety from this general approval.

The wood preservative treated lumber and plywood are approved for use subject to the following conditions:

1. All preservative treated lumber and plywood used on exterior walls shall be protected by a weather barrier in accordance with Section 1403 of the 2011 Los Angeles City Building Code.
2. Approval for aluminum and mild steel fasteners with PACBOR preservative treated wood products is limited to interior applications.

RR25905
Page 1 of 2

DISCUSSION

The report is in compliance with the 2011 Los Angeles City Building Code.

The approval is based on data in accordance with Appendix J [Disodium Octaborate Tetrahydrate (DOT) Wood Preservative Systems (Formerly AC62)] of the ICC-ES Acceptance Criteria for Proprietary Wood Preservative Systems- Common Requirements for Treatment Process, Test Methods and Performance (AC 326), dated June 2009.

This general approval will remain effective provided the Evaluation Report is maintained valid and unrevised with the issuing organization. Any revisions to the report must be submitted to this Department, with appropriate fee, for review in order to continue the approval of the revised report.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this approval have been met in the project in which it is to be used.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

ALLEN PEERY, Chief
Engineering Research Section
201 N. Figueroa St., Room 880
Los Angeles, CA 90012
Phone- 213-202-9812
Fax- 213-202-9943

WS:
RR25905/MSWord2010
R08/13/12
3D1/2303.1.8/2304.11.6

Attachment: ICC ES Evaluation Service Report No. ESR-3038 (4 Pages).

RR25905
Page 2 of 2