

BOARD OF
**BUILDING AND SAFETY
COMMISSIONERS**

VAN AMBATIELOS
PRESIDENT

E. FELICIA BRANNON
VICE PRESIDENT

JOSELYN GEAGA-ROSENTHAL
GEORGE HOVAGUIMIAN
JAVIER NUNEZ

CITY OF LOS ANGELES
CALIFORNIA



ERIC GARCETTI
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

FRANK M. BUSH
GENERAL MANAGER
SUPERINTENDENT OF BUILDING

OSAMA YOUNAN, P.E.
EXECUTIVE OFFICER

SAFTIFIRST/O'Keeffe's, Inc.
100 N. Hill Drive, Suite 12
Brisbane, CA 94005-1010

Attn: Diana San Diego
(415) 824 4900

RESEARCH REPORT: RR 25655
(CSI # 08800)

Expires: April 1, 2020
Issued Date: February 1, 2018
Code: 2017 LABC

GENERAL APPROVAL –Renewal and Clerical Modification - SuperLite 1-XL 45 minutes and 60 minutes fire-rated glazing.

DETAILS

Door:

Steel, 3'-0" wide x 7'-0" high.

Door & Sidelight Frame:

Listed, 16 gauge hollow-metal, suitable for drywall, Jamb depth 5-7/8".

Glazing material:

1/4" SuperLite 1- XL with 5/8" high x 1-1/4" wide stops.

1/8" x 1/2" fiberglass knit tape.

1/4" x 1/4" x 3" Silicon Setting Block.

The approval is subject to the following conditions:

1. SuperLite 1- XL fire rated glazing and pertinent hardware shall bear Intertek Testing Services NA Inc. labels.
2. SuperLite 1- XL fire rated glazing shall be installed in accordance with the manufacturers instruction, the listing, this research report, and the 2017 Los Angeles City Building Code.
3. This product reflects radiant heat from one direction only when provided as a monolithic unit and all directions when provided as an insulated unit. When the monolithic unit is used, the surface having the heat reflective coating shall be installed facing the direction of the expected fire.

RR25655
Page 1 of 2

SAFTIFIRST/O’Keeffe’s, Inc

RE: SuperLite 1-XL 45 minutes and 60 minutes fire-rated glazing.

4. The product shall be installed with heat reflective surface (surfaces) facing fire sprinklers when present.
5. The SuperLite 1-XL fire rated glazing shall be labeled in accordance with the requirements of section 716.5.8.3 of the 2017 Los Angeles City Building Code.

DISCUSSION

The clerical modification is to change the contact name and phone number as well as updating the report to the 2017 Los Angeles City Building Code.

The report is in compliance with the 2017 Los Angeles City Building Code.

The approval is based on fire test in accordance with ASTM E-119 but does not meet the hose stream requirement.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this Approval have been met in the project in which it is to be used.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

QUAN NGHIEM, Chief
Engineering Research Section
201 N. Figueroa St., Room 880
Los Angeles, CA 90012
Phone- 213-202-9812
Fax- 213-202-9943

QN
RR25655/MSWord2013
R01/26/2018
TLB1800012
703.3/ 716.5.8.3