

# CITY OF LOS ANGELES

CALIFORNIA

BOARD OF  
**BUILDING AND SAFETY**  
COMMISSIONERS

VAN AMBATIELOS  
PRESIDENT

E. FELICIA BRANNON  
VICE PRESIDENT

JOSELYN GEAGA-ROSENTHAL  
GEORGE HOVAGUIMIAN  
JAVIER NUNEZ



ERIC GARCETTI  
MAYOR

DEPARTMENT OF  
**BUILDING AND SAFETY**  
201 NORTH FIGUEROA STREET  
LOS ANGELES, CA 90012

FRANK M. BUSH  
GENERAL MANAGER  
SUPERINTENDENT OF BUILDING

OSAMA YOUNAN, P.E.  
EXECUTIVE OFFICER

Mitek USA, INC.  
(Formerly USP Structural Connectors)  
14305 Southcross Drive, Suite 200  
Burnsville, MN 55306

Attn: Steve Brekke, P.E.  
(952) 898-8772

RESEARCH REPORT: RR 25992  
(CSI #03 16 00)

BASED UPON ICC-ES EVALUATION  
REPORT NO. ESR-2266

REEVALUATION DUE  
DATE: January 1, 2020  
Issued Date: December 1, 2017  
Code: 2017 LABC

**GENERAL APPROVAL** – Reevaluation/Clerical Modification - USP Structural Connectors  
Proprietary STB and STBL Anchor Bolt Series Cast in Place Anchor Bolts

## DETAILS

When in compliance with the use, description, design, installation, conditions of approval, and identification of Evaluation Report No. 2266 reissued March, 2017 of the ICC-ES Evaluation Services, Incorporated. The report, in its entirety, is attached and made part of this general approval.

The parts of the ES Report, ESR-3050, which are excluded on the attached copy have been removed by the Los Angeles Building Department as not being included in this approval.

### **The approval is subject to the following conditions:**

1. Periodic special inspection is required for installation of connectors that are used as part of the seismic or wind force-resisting system.
2. The products described in this report are identified as described in the attached ESR-2266.
3. The allowable loads specified in this approval are for the wood fastening devices and its fasteners and does not include supporting members.

RR 25992  
Page 1 of 2

USP Structural Connectors, A MiTek® Company

RE: USP Structural Connectors Proprietary STB and STBL Anchor Bolt Series Cast in Place Anchor Bolts

**DISCUSSION**

The clerical modification is to change the contact person name and phone number and update the report the 2017 City of Los Angeles Building Code.

This report is in compliance with the 2017 City of Los Angeles Building Code.

The approval is based on tests and analyses in accordance with ICC-ES AC 399, dated February 2017.

This general approval will remain effective provided the Evaluation Report is maintained valid and unrevised with the issuing organization. Any revision to the report must be submitted to this Department for review with appropriate fee to continue the approval of the revised report.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this Approval have been met in the project in which it is to be used.

---

QUAN NGHIEM, Chief  
Engineering Research Section  
201 N. Figueroa St., Room 880  
Los Angeles, CA 90012  
Phone - 213-202-9812  
Fax - 213-202-9943

QN  
RR25992  
R12/04/2017  
TLB1700411  
1604.8.1, 1901.3

Attachments: ICC-ES Evaluation Report No. ESR-2266 (5 Pages).