

CITY OF LOS ANGELES

CALIFORNIA



ERIC GARCETTI
MAYOR

BOARD OF
**BUILDING AND SAFETY
COMMISSIONERS**

—
VAN AMBATIELOS
PRESIDENT

E. FELICIA BRANNON
VICE-PRESIDENT

JOSELYN GEAGA-ROSENTHAL
GEORGE HOVAGUIMIAN
JAVIER NUNEZ

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

—
RAYMOND S. CHAN, C.E., S.E.
GENERAL MANAGER

FRANK BUSH
EXECUTIVE OFFICER

United Metal Products
234 N. Sherman Avenue
Corona, CA. 92882

Attn: Bob Swist
(951) 739-9535

RESEARCH REPORT: RR 25319

Expires: November 1, 2016
Issued Date: September 1, 2014
Code: 2014 LABC

GENERAL APPROVAL – Renewal/ Clerical Modification – Metal Lite Slotted Track.

DETAILS

Metal Lite Slotted Track for use with metal stud walls consists of $\frac{5}{8}$ " type gypsum wallboard, 22 gauge metal studs, 22 gauge x 2½" top track and 3.5 pcf density mineral wool insulation.

The approval is subject to the following conditions:

1. When the system is installed to the underside of a composite deck sprayed with fireproofing material, the fireproofing material **shall not** be removed.
2. Installation shall follow manufacturer's instructions and attached details.

DISCUSSION

The report is in compliance with the 2014 City of Los Angeles Building Code.

Fire-resistive joist system test meets the 2014 Los Angeles City Building Code.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this approval have been met in the project in which it is to be used.

RR 25319
Page 1 of 2

United Metal Products
RE: Metal Lite Slotted Track

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

ALLEN PEERY, Chief
Engineering Research Section
201 N. Figueroa St., Room 880
Los Angeles, CA 90012
Phone - 213-202-9812
Fax - 213-202-9942

QN
R:25319/MSWord2010
R08/16/14
706

Attachments: (10 Pages)