

CITY OF LOS ANGELES
CALIFORNIA

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

VAN AMBATIELOS
PRESIDENT

E. FELICIA BRANNON
VICE PRESIDENT

JOSELYN GEAGA-ROSENTHAL
GEORGE HOVAGUIMIAN
JAVIER NUNEZ



ERIC GARCETTI
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

FRANK M. BUSH
GENERAL MANAGER
SUPERINTENDENT OF BUILDING

OSAMA YOUNAN, P.E.
EXECUTIVE OFFICER

Hill Brothers Chemical Company
c/o Desert Brand Products
1675 N. Main Street
Orange, CA 92867

Attn: Tony Garcia
(626) 435-8591

RESEARCH REPORT: RR 25262
(CSI # 07 18 13)

BASED UPON ICC ES EVALUATION SERVICE
REPORT NO. ESR-1661

REEVALUATION DUE

DATE: August 1, 2019
Issued Date: November 1, 2017
Code: 2014 LABC

GENERAL APPROVAL – Reevaluation - Desert Crete and Desert Brand Magnesite Fire Retardant Walking Deck and Roof Covering System.

DETAILS

The above assemblies and/or products are approved when in compliance with the description, use, identification and findings of Evaluation Report No. ESR-1661, reissued February 1, 2014, revised May 2015, of the ICC Evaluation Service, LLC. The report, in its entirety, is attached and made part of this general approval.

The parts of Evaluation Report No. ESR-1661 marked by an asterisk are modified or deleted by the Los Angeles City Building Department from this approval.

The approval is subject to the following conditions:

1. The deck system components (except for felt and galvanized metal lath, where appropriate) shall be delivered to the job sites in sealed containers identified by the manufacturer's name and product designation.
2. The application of the components shall be in accordance with this report and the manufacturer's instructions. A copy of the instructions shall be available at the job site. Wood structural panels shall be clean and dry prior to application of system.

RR 25262
Page 1 of 2

Hill Brothers Chemical Company

RE: Desert Crete and Desert Brand Magnesite Fire Retardant Walking Deck and Roof Covering System.

DISCUSSION

The report is in compliance with the 2014 Los Angeles City Building Code.

Satisfactory test data have been submitted and are on file in the office of the Engineering Research Section.

This general approval will remain effective provided the Evaluation Report is maintained valid and unrevised with the issuing organization. Any revisions to the report must be submitted to this Department, with appropriate fee, for review in order to continue the approval of the revised report.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this approval have been met in the project in which it is to be used.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

QUAN NGHIEM, Chief
Engineering Research Section
201 N. Figueroa St., Room 880
Los Angeles, CA 90012
Phone- 213-202-9812
Fax- 213-202-9943

QN
RR25262
R10/21/2017
TLB1700360
1505

Attachment: ICC ES Evaluation Report No. ESR-1661 (4 pages)
ESR-1661 CBC and CRC Supplement (1 page)