

CITY OF LOS ANGELES
CALIFORNIA

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

VAN AMBATIELOS
PRESIDENT

E. FELICIA BRANNON
VICE PRESIDENT

JOSELYN GEAGA-ROSENTHAL
GEORGE HOVAGUIMIAN
JAVIER NUNEZ



ERIC GARCETTI
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

FRANK M. BUSH
GENERAL MANAGER
SUPERINTENDENT OF BUILDING

OSAMA YOUNAN, P.E.
EXECUTIVE OFFICER

Aaron Berc
Ecolab, Inc.
370 N. Wabasha Street
St. Paul, MN 55102

Telephone: 651-795-5698

Models:

Outback and Caravan II | XP/ Whiteout Power Foamer

File Number: M-080200

Effective Date: 03/15/2017

Expiration Date: 02/01/2018

Manufacturer: SAME

Item: CHEMICAL DISPENSER

PLEASE REFER TO THE APPLICATION NUMBER ON ALL CORRESPONDENCE, PHONE CALLS & SAMPLES

The item processed under the above file number has been tested, examined and found to comply with applicable Los Angeles Plumbing Code (LAPC) and/or Los Angeles Mechanical Code (LAMC) and is hereby approved unless revoked for cause.

This letter or the letterhead copy may not be reproduced for use in labeling or advertising, but copies of this letter may be used within your organization and shown as evidence of approval.

CONDITIONS OF APPROVAL:

- 1. These chemical dispensers may be installed in a commercial building. They may be connected to a potable water supply, of which temperature does not exceed 140 deg. F., and pressure is between 20 psi. minimum to 80 psi. maximum.**
- 2. Potable water supply inlet of this product shall be protected by an approved reduced- pressure principle backflow prevention assembly (RP) per Section 94.603.5.6.3 of LAPC, 2017 Edition.**
- 4. These products shall be installed, operated and maintained in accordance with printed instructions from the manufacturer by trained personnel only.**

Each item shall have the name or trademark of manufacturer and model number where it will be visible for inspection.

In order to renew this approval, an application and reexamination fee must be submitted on or before the expiration date shown above. Arrangement shall be made to remove any test samples remaining in the Laboratory. Samples remaining after 21 days from the date of this notice will be shipped collect by the most convenient carrier or disposed of in accordance with applicable regulation.

William J Miranda
Mechanical Testing Laboratory, Test Engineer