

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

MARSHA L. BROWN
PRESIDENT

VAN AMBATIELOS
VICE-PRESIDENT

VICTOR H. CUEVAS
HELENA JUBANY
ELENORE A. WILLIAMS

CITY OF LOS ANGELES

CALIFORNIA



ANTONIO R. VILLARAIGOSA
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

RAYMOND S. CHAN, C.E., S.E.
INTERIM GENERAL MANAGER

CBS Outdoor
1731 Workman Street
Los Angeles, CA 90031

Attn: Andy Goodman
(323) 276-7231

RESEARCH REPORT: RR 25761
(CSI # 08840)

Expires: March 1, 2012
Issued Dates: November 1, 2009
Code: 2008 LABC

GENERAL APPROVAL – Renewal - 3M MMT-022 Mesh Vinyl Sheet for super-graphics, temporary wall signs and temporary displays on walls and billboards.

DETAILS

3M MMT-022 Mesh Vinyl Sheet is an approved plastic material. The plastic sheet has flame spread index of 10 and smoke development index of 250.

This approval is subject to the following conditions:

1. Plastic sheets shall be identified by manufacturer's name and product designation.
2. The use of the plastic sheets is for super-graphics, temporary wall signs and temporary displays on walls and billboards.
3. The plastic sheets shall be labeled with flame spread index of 10, smoke development index of 250 and plastic classification of CC1.
4. Building permit is required for the use of plastic sheet for super-graphics temporary wall signs and temporary displays on walls. Architectural plans and details of installation shall be submitted to plan check for review and approval.
5. The fire department approval is required for plastic sheets on **all buildings**.

RR 25761
Page 1 of 2

CBS Outdoor
RE: 3M MMT-022 Mesh Vinyl Sheet

DISCUSSION

The report is in compliance with 2008 Los Angeles Building Code.

Per memo from LAFD to LADBS, dated March 16, 2009, all graphics of this type to be installed or utilized in any manner, on any part of any structure, shall be submitted to the LAFD for plan review. Los Angeles Fire Code Division 15 plan review fees will apply.

The approval is based on tests of ASTM E 84 and UBC Standard No.26-7.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this approval have been met in the project in which it is to be used.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

YEUAN CHOU, Chief
Engineering Research Section
201 N. Figueroa St., Room 880
Los Angeles, CA 90012
Phone (213) 202-9812
Fax (213) 202-9942

TV:tvo
RR25761/MSWord2003
R11/01/09
6C/0217/2606

Attachment - LAFD Memo (1 Page)