

CITY OF LOS ANGELES
CALIFORNIA

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

VAN AMBATIELOS
PRESIDENT

E. FELICIA BRANNON
VICE PRESIDENT

JOSELYN GEAGA-ROSENTHAL
GEORGE HOVAGUIMIAN
JAVIER NUNEZ



ERIC GARCETTI
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

FRANK M. BUSH
GENERAL MANAGER
SUPERINTENDENT OF BUILDING

OSAMA YOUNAN, P.E.
EXECUTIVE OFFICER

CBS Outdoor
1731 Workman Street
Los Angeles, CA 90031

Attn: Andy Goodman
(323) 276-7231

RESEARCH REPORT: RR 25760
(CSI # 08840)

Expires: January 1, 2020
Issued Date: December 1, 2017
Code: 2017 LABC

GENERAL APPROVAL – Renewal – 3MIJ35-20 Sticky Back Vinyl Sheet for temporary signs, special temporary displays, supergraphics, permanent wall signs and billboards.

DETAILS

3MIJ35-20 Sticky Back Vinyl Sheet is an approved plastic material. The plastic sheet has flame spread index of 0 and smoke development index of 15.

This approval is subject to the following conditions:

1. Plastic sheets shall be identified by manufacturer's name and product designation.
2. The use of the plastic sheets is for supergraphics, temporary signs and temporary displays on walls and billboards.
3. The plastic sheets shall be labeled with flame spread index of 0, smoke development index of 15 and plastic classification of CC1.
4. Building permit is required for the use of plastic sheet for supergraphics, temporary signs and temporary displays on walls. Architectural plans and details of installation shall be submitted to plan check for review and approval.
5. The fire department approval is required for plastic sheets on **all buildings**.

R 25760
Page 1 of 2

CBS Outdoor
RE: 3MIJ35-20 Sticky Back Vinyl Sheet

DISCUSSION

This report is in compliance with the 2017 City of Los Angeles Building Code.

Per memo from LAFD to LADBS, dated December 22, 2009, all graphics of this type to be installed or utilized in any manner, on any part of any structure, shall be submitted to the LAFD for plan review. Los Angeles Fire Code Division 15 plan review fees will apply.

The approval is based on tests of ASTM D635-06, ASTM E 84 AND UBC Standard 26-7.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this approval have been met in the project in which it is to be used.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

QUAN NGHIEM, Chief
Engineering Research Section
201 N. Figueroa St., Room 880
Los Angeles, CA 90012
Phone- 213-202-9812
Fax- 213-202-9943

QN
RR25760
TLB1700422
R12/9/17
2606.4/6207.1.1

Attachment: LAFD Memo (1 Page)