

CITY OF LOS ANGELES
CALIFORNIA

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

VAN AMBATIELOS
PRESIDENT

E. FELICIA BRANNON
VICE PRESIDENT

JOSELYN GEAGA-ROSENTHAL
GEORGE HOVAGUIMIAN
JAVIER NUNEZ



ERIC GARCETTI
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

FRANK BUSH
INTERIM GENERAL MANAGER

Simpson Strong-Tie Company, Inc.
12246 Holly Street
Riverside, CA 92509

Attn: Tim Kaucher, P. E.
(714) 738-2151

RESEARCH REPORT: RR 25714
(CSI # 06 05 23)

BASED UPON ICC EVALUATION SERVICE
REPORT NO. ESR-2604

REEVALUATION DUE

DATE: September 1, 2018
Issued date: August 1, 2016
Code: 2014 LABC

GENERAL APPROVAL – Reevaluation - Simpson Strong-Tie Column Caps for wood construction

1. CC, ECC, CCQ and ECCQ Column Caps
2. AC, EAC, LPC, PC, EPC, BC, BCS, EPCZ, AND PCZ Post Caps

DETAILS

The above assemblies and/or products are approved when in compliance with the use, description, design, installation, conditions of use, and identification of Evaluation Report No. ESR-2604, reissued January 1, 2016 of the ICC Evaluation Service, LLC. The report, in its entirety, is attached and made part of this general approval.

The parts of Report No. ESR-2604 which are excluded on the attached copy have been removed by the Los Angeles Building Department as not being included in this approval.

The approval is subject to the following conditions:

1. Calculations and details to show compliance with this report shall be submitted to Structural Plan Check for review and approval. Calculations and details shall be prepared, signed, and sealed by California licensed engineer.
2. The connections are not approved to resist uplift forces from wood shear walls.

RR 25714
Page 1 of 2

Simpson Strong-Tie Company, Inc.
RE: Simpson Strong-Tie Column Caps for Wood Construction

3. Allowable loads must be reduced when load durations with lower value of C_D (than what is in the tables) govern.

DISCUSSION

The report is in compliance with the 2014 City of Los Angeles Building Code.

The approval is based on data in accordance with the ICC-Acceptance Criteria (AC-13).

This general approval will remain effective provided the Evaluation Report is maintained valid and unrevised with the issuing organization. Any revision to the report must be submitted to this Department for review with appropriate fee to continue the approval of the revised report.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this Approval have been met in the project in which it is to be used.

QUAN NGHIEM, Chief
Engineering Research Section
201 N. Figueroa St., Room 880
Los Angeles, CA 90012
Phone- 213-202-9812
Fax- 213-202-9943

DE
RR25714/MSWord2010
R08/01/16
TLB1600187
5D2/2304.9

Attachments: ICC ES ESR-2604 (10 Pages)