

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

MARSHA L. BROWN
PRESIDENT

VAN AMBATIELOS
VICE-PRESIDENT

VICTOR H. CUEVAS
HELENA JUBANY
ELENORE A. WILLIAMS

CITY OF LOS ANGELES

CALIFORNIA



ANTONIO R. VILLARAIGOSA
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

ROBERT R. "BUD" OVROM
GENERAL MANAGER

RAYMOND S. CHAN, P.E., S.E.
EXECUTIVE OFFICER

Decra Roofing Systems, Inc.
1230 Railroad St.
Corona, CA 92882

Attn: David Eloredege
(951) 272-8180 ext. 210

RESEARCH REPORT: RR 25463
(CSI # 07410)

BASED UPON ICC EVALUATION
REPORT NO. ESR-1483

REEVALUATION DUE DATE:

October 1, 2011

Issued Date: October 1, 2010

Code: 2008 LABC

GENERAL APPROVAL- Decra Shingle Steel Roofing Panels

DETAILS

The above assemblies and/or products are approved when in compliance with the description, use, identification and findings of Report No. ESR-1483, reissued December 1, 2009, of the ICC Evaluation Service, Incorporated. The report, in its entirety, is attached and made part of this general approval.

The parts of Report No. ESR-1483 marked by the asterisk are modified by the Los Angeles City Building and Safety Department from this approval.

Conditions of Approval:

1. The roof coverings may be installed over existing Asphalt Shingles or Built-Up roofs. All other existing roof coverings must be completely removed and the panels installed in accordance with Section 4.2 of the ICC ESR-1483.
2. Except as specified herein, installations of the panels shall be in accordance with the manufacturer's instructions
3. The roof coverings shall be installed over roofs with slopes of at least 3:12 or 25%
4. For all new constructions, including additions, the roof panels shall be installed on solid

RR 25463
Page 1 of 2

Decra Roofing Systems, Inc
RE: Decra Shingle Steel Roofing Panels

sheathing complying with the 2008 Los Angeles City Building Code.

5. Reroofing applications shall comply with Section 4.3 of ICC ERS-1483 and Section 1510 of the 2008 Los Angeles City Building Code.
6. Decra Shingle Steel Roofing Panels installed in accordance with Sections 4.2 or 4.3 of the ICC ESR 1483 are recognized as Class A roof assemblies under the 2008 Los Angeles City Building Code.

DISCUSSION

The report is in compliance with the 2008 Los Angeles City Building Code.

This approval is based on tests and performance requirements in accordance with the ICC-ES Acceptance Criteria for Metal Roof Coverings (AC166), dated May 2008.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this approval have been met in the project in which it is to be used.

This general approval will remain effective provided the Evaluation report is maintained valid and unrevised with the issuing organization. Any revisions to the report must be submitted to this Department, with appropriate fee, for review in order to continue the approval of the revised report.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

WILLIAM STUTSMAN, Chief
Engineering Research Section
201 N. Figueroa St., Room 880
Los Angeles, CA 90012
Phone (213) 202-9812
Fax (213) 202 -9943

KH:kh
RR25463/MSWord2007
R09/08/10
4C/1504

Attachment: ICC ES Evaluation Report No.ESR-1483 (4 pages)

RR 25463
Page 2 of 2