

CITY OF LOS ANGELES
CALIFORNIA

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

VAN AMBATIELOS
PRESIDENT

E. FELICIA BRANNON
VICE PRESIDENT

JOSELYN GEAGA-ROSENTHAL
GEORGE HOVAGUIMIAN
JAVIER NUNEZ



ERIC GARCETTI
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

FRANK M. BUSH
GENERAL MANAGER
SUPERINTENDENT OF BUILDING

OSAMA YOUNAN, P.E.
EXECUTIVE OFFICER

Wilsonart International, Inc.
Post Office Box 6110
Temple, TX 76503-6110

Attn: John Snow
(254) 207-2371

Local Representative:
Scott Siracusa
562-921-7426

RESEARCH REPORT: RR 25183
(CSI # 09770)

Expires: June 1, 2020
Issued Date: May 1, 2018
Code: 2017 LABC

GENERAL APPROVAL – Renewal & Clerical Modification - Wilsonart Gibraltar Solid Surfacing Acrylic Blend and Acrylic Panels for use as an interior plastic veneer

DETAILS

Wilsonart Gibraltar Solid Surfacing Acrylic Blend Panels are manufactured of polyester and acrylic resins fire-retardant fillers and, proprietary coloring agents. The panels are manufactured in thicknesses of ¼", ½" and ¾". Each panel thickness has a class I flame spread index and a smoke density rating less than 150.

Wilsonart Gibraltar Solid Surfacing Acrylic Panels are manufactured of acrylic resins with fire-retardant fillers and proprietary coloring agents. The panels are manufactured in a thickness of ½-inch. The panel has a class I flame spread index and a smoke density rating less than 150.

Panels require a supporting framework that must be approved by Structural Plan Check.

The approval is subject to the following conditions:

1. The panels are approved for use as interior plastic veneer in accordance with Section 2605 of the 2017 Los Angeles City Building Code.

RR 25183
Page 1 of 2

Wilsonart International, Inc.

RE: Wilsonart Gibraltar Solid Surfacing Acrylic Blend and Acrylic Panels.

DISCUSSION

The report is in compliance with the 2017 Los Angeles City Building Code.

The approval is based on tests in accordance with ASTM Standard E84.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this approval have been met in the project in which it is to be used.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

QUAN NGHIEM, Chief
Engineering Research Section
201 N. Figueroa St., Room 880
Los Angeles, CA 90012
Phone- 213-202-9812
Fax- 213-202-9943

QN
RR25183/MSWord2013
R04/29/2018
TLB1800111
2605