

CITY OF LOS ANGELES  
CALIFORNIA

BOARD OF  
BUILDING AND SAFETY  
COMMISSIONERS

VAN AMBATIELOS  
PRESIDENT

E. FELICIA BRANNON  
VICE PRESIDENT

JOSELYN GEAGA-ROSENTHAL  
GEORGE HOVAGUIMIAN  
JAVIER NUNEZ



ERIC GARCETTI  
MAYOR

DEPARTMENT OF  
BUILDING AND SAFETY  
201 NORTH FIGUEROA STREET  
LOS ANGELES, CA 90012

FRANK M. BUSH  
GENERAL MANAGER  
SUPERINTENDENT OF BUILDING

OSAMA YOUNAN, P.E.  
EXECUTIVE OFFICER

Hilti, Incorporated  
7520 Dallas Parkway, Suite 1000  
Plano, TX 75024

Attn: Jennifer Ray  
(972) 403-5995

RESEARCH REPORT: RR 26027  
(CSI # 13 16 00)

BASED UPON ICC EVALUATION SERVICE  
ES REPORT NO. ESR-3829

REEVALUATION DUE  
DATE: April 01, 2021  
Issued Date: April 01, 2019  
Code: 2017 LABC

**GENERAL APPROVAL** – Reevaluation - Hilti HIT-RE 100 Adhesive Anchors in Cracked and Uncracked Concrete.

## DETAILS

The above assemblies and/or products are approved when in compliance with the use, description, design, installation, conditions of use, and identification of Evaluation Report No. ESR-3829, reissued April 2018, revised April 24, 2018, subject to renewal 2020 of the ICC Evaluation Service, LLC. The report, in its entirety, is attached and made part of this general approval.

The parts of Report No. ESR-3829, which are marked by the asterisks, are deleted or revised by the Los Angeles City Building Department from this approval.

### The approval is subject to the following conditions:

1. The design information listed in the attached report and tables are valid for the fasteners only. Connected members shall be checked for their capacity (which may govern).
2. Design information, edge distances, spacing and minimum embedment requirements shall be per Tables in ICC-ES Report No. ESR-3829.

RR 26027  
Page 1 of 3

Hilti, Inc.

RE: Hilti HIT-RE 100 Adhesive Anchors In Concrete.

3. Prior to installation, calculations and details demonstrating compliance with this approval letter and the 2017 Los Angeles Building Code must be submitted the structural plan check division for review. The calculations and details must be prepared by a licensed civil or structural engineer registered in the state of California.
4. Special inspection in accordance with Section 1705.3 of the 2017 Los Angeles City Building Code shall be provided for anchor installations.
5. The anchors shall be installed as per the attached manufacturer's instructions except as otherwise stated in this report. Copies of the installation instructions shall be available at each job site.
6. The adhesive anchors shall not be used to support fire-resistive construction unless in compliance with Section 5.12 of the attached ICC-ES ESR-3829.
7. Minimum concrete cover per Chapter 20.6.1 of the ACI 318-14 shall be followed whenever applicable.
8. The anchors shall be identified by labels on the packaging indicating the manufacturer's name and product designation.
9. Attachment to masonry in outside the scope of this approval.

## **DISCUSSION**

The report is in compliance with 2017 Los Angeles Building Code.

This approval is based on data in accordance with ICC-ES Acceptance Criteria for Post-installed Adhesive Anchors in Concrete (AC308), dated January 2016, which incorporates requirements in ACI 355.4-11.

This general approval will remain effective provided the Evaluation Report is maintained valid and unrevised with the issuing organization. Any revision to the report must be submitted to this Department for review with appropriate fee to continue the approval of the revised report.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction, which must be approved, by Department of Building and Safety Engineers and Inspectors.

Hilti, Inc.

RE: Hilti HIT-RE 100 Adhesive Anchors In Concrete.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this Approval have been met in the project in which it is to be used.

Hilti offers software to assist in the design of anchorages using Hilti products.

---

DAVID CHANG, Chief  
Engineering Research Section  
201 N. Figueroa St., Room 880  
Los Angeles, CA 90012  
Phone- 213-202-9812  
Fax- 213-202-9943

BKR  
RR26027  
TLB1900095  
R04/02/2019  
1901.3, 1905.1.3, ACI 318-14, ch. 17

Attachment: ICC ES Report No. ESR-3829 (32 Pages)