

CITY OF LOS ANGELES
CALIFORNIA

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

VAN AMBATIELOS
PRESIDENT

E. FELICIA BRANNON
VICE PRESIDENT

JOSELYN GEAGA-ROSENTHAL
GEORGE HOVAGUIMIAN
JAVIER NUNEZ



ERIC GARCETTI
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

FRANK M. BUSH
GENERAL MANAGER
SUPERINTENDENT OF BUILDING

OSAMA YOUNAN, P.E.
EXECUTIVE OFFICER

GCP Applied Technologies
62 Whittemore Avenue
Cambridge, MA 02140

Attn: Mark Franciosi
(617) 498-4303

RESEARCH REPORT: RR 25392
(CSI #07100)

Expires: April 01, 2021
Issued Date: April 01, 2019
Code: 2017 LABC

GENERAL APPROVAL – Renewal - Procor® Fluid Applied Waterproofing Membranes for below-grade concrete and masonry walls and concrete slab.

DETAILS

Procor® Fluid Applied Waterproofing Membranes are two parts, self-curing, rubber based materials. The two parts are mixed together on site prior to use and are cold applied to the substrate.

The above system is approved for waterproofing when required by Sections 1805.2 and 1805.3 of the 2017 Los Angeles City Building Code.

Applications of the materials for the system shall be in accordance with the manufacturer's instructions, a copy of which shall be provided, at each jobsite.

The approval is subject to the following conditions:

1. Insulation, if used, must be installed over the membrane.
2. Do not apply Procor Membranes over lightweight insulating concrete.
3. The shelf life is nine months in unopened containers. Shelf life will be reduced if stored in temperatures above 90 degree Fahrenheit. Refer to product label and Material Safety Data Sheet (MSDS) before use.
4. Allow Procor Waterproofing Membrane to cure at least 24 hours prior to backfill and at least 48 hours prior to flood testing.

RR 25392
Page 1 of 2

DISCUSSION

The report is in compliance with the 2017 City of Los Angeles Building Code.

The approval is based on tests.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this Approval have been met in the project in which it is to be used.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

DAVID CHANG, Chief
Engineering Research Section
201 N. Figueroa St., Room 880
Los Angeles, CA 90012
Phone - 213-202-9812
Fax - 213-202-9943

BKR
RR25392
R04/10/2019
TLB1900091
1805.2/1805.3