

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

MARSHA L. BROWN
PRESIDENT

VAN AMBATIELOS
VICE-PRESIDENT

VICTOR H. CUEVAS
HELENA JUBANY
ELENORE A. WILLIAMS

CITY OF LOS ANGELES

CALIFORNIA



ANTONIO R. VILLARAIGOSA
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

ROBERT R. "BUD" OVROM
GENERAL MANAGER

RAYMOND S. CHAN, P.E., S.E.
EXECUTIVE OFFICER

Clear Focus Imaging, Inc.
60 Maxwell Court
Santa Rosa, CA 95401

Attn: Judy Bellah
(707) 544-7990

RESEARCH REPORT: RR 25817
(CSI # 08840)

Expires: September 1, 2012
Issued Date: July 1, 2010
Code: 2008 LABC

GENERAL APPROVAL – Renewal - Clear Focus ClassicVue® perforated, pressure-sensitive window graphics film for temporary signs, special temporary displays, supergraphics, permanent wall signs and billboards.

DETAILS

Clear Focus ClassicVue® perforated, pressure-sensitive window graphics film is an approved plastic material. ClassicVue graphics film has flame spread index of 10 and smoke development index of 25.

This approval is subject to the following conditions:

1. ClassicVue graphics film shall be identified by manufacturer's name and product designation.
2. Size, location, and use of graphics film shall be in accordance with Section 2606 of the 2008 Los Angeles City Building Code.
3. The ClassicVue graphics film shall be labeled with flame spread index of 10, smoke development index of 25 and plastic classification of CC1. Architectural plans and details of installation shall be submitted to plan check for review and approval.
4. The fire department approval is required for ClassicVue graphics film **on all buildings.**

Clear Focus Imaging, Inc.

RE: Clear Focus ClassicVue® perforated, pressure-sensitive window graphics film.

DISCUSSION

The report is in compliance with 2008 Los Angeles Building Code.

Per memo from LAFD to LADBS, dated on September 2, 2009, all graphics of this type to be installed or utilized in any manner, on any part of any structure, shall be submitted to the LAFD for plan review. Los Angeles Fire Code Division 15 plan review fees will apply.

The approval is based on tests of ASTM E 84-08 and UBC Standard No. 26-6 and 26-7. This material meets the requirements for an approved plastic per 6207.1.1 of the 2008 Los Angeles City Building Code.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this approval have been met in the project in which it is to be used.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

WILLIAM STUTSMAN, Chief
Engineering Research Section
201 N. Figueroa St., Room 880
Los Angeles, CA 90012
Phone - 213-202-9812
Fax - 213-202-9943

TV: tvo
RR25817/MSWord2007
R07/01/10
6C/2606/6207