

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

JAVIER NUÑEZ
PRESIDENT

MARSHA L. BROWN
VICE-PRESIDENT

VAN AMBATIELOS

PEDRO BIRBA

ELENORE A. WILLIAMS

CITY OF LOS ANGELES
CALIFORNIA



ANTONIO R. VILLARAIGOSA
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

ANDREW A. ADELMAN, P.E.
GENERAL MANAGER

RAYMOND CHAN
EXECUTIVE OFFICER

Tremco Inc.
3735 Green Road
Beachwood, OH 44122

RESEARCH REPORT: RR 25593
(CSI #07120)

Expires: December 1, 2008

Attn: Wes Hensley
(216) 766-5531

GENERAL APPROVAL - Renewal - TREMproof® 260 for Below-Grade Waterproofing Membrane and Gas Barrier.

DETAIL

TREMproof® 260 is a spray-applied, polymer enhanced, single component, fluid-applied asphalt emulsion for Below-Grade Waterproofing Membrane and Gas Barrier. The TREMproof® 260 may be co-sprayed with calcium chloride as a two-part material.

The TREMproof® 260 applied to Typar 3401 geotextile composite fabric is measured 60 mils minimum in thickness for Below-Grade Waterproofing Membrane and Gas Barrier.

This product is approved for below-grade waterproofing membrane and gas barrier subject to the following conditions:

1. The TREMproof® 260 shall be supplied in clearly marked containers bearing the brand name and product identification.
2. The manufacturer shall provide quality assurance of the materials supplied as to their formulation.
3. Application of the product shall be accomplished by an applicator approved by the manufacturer. A written statement by the manufacturer stating that the applicator is an approved applicator is required prior to use of the product.

RR 25593
Page 1 of 3

Tremco Inc.

RE: TREMproof® 260 for Below Grade Waterproofing Membrane and Gas Barrier

4. All surfaces to receive membrane shall be free of laitance, sharp projections, oil, dirt or other contaminants. Prepare surfaces in accordance with the manufacturer's instructions.
5. Installation of the materials shall be in accordance with the manufacturer's instructions, a copy of which shall be kept at the job site.
6. Complete details for the membrane system are submitted for plan check and a building permit is obtained.
7. The following field tests in accordance with the Tremco Inc. Field Installation and Repair Procedure are required: (A copy of the Installation and Repair Procedures is on file with Engineering Research Section.)
 - a. Perform Thickness Sample Test at every 500 square feet.
 - b. Perform Smoke Test for the entire site at the interval not more than 50,000 sq. ft. each.
8. Protection for the membrane shall be provided in accordance with the written instructions by the engineer of the record.
9. Prior to placing the concrete slab over the membrane, the membrane installer shall certify the membrane to be installed and tested in accordance with the manufacturer's specifications and to be free of leaks.
10. The membrane is not to be placed under the building footings.
11. For gas membrane installations, continuous inspection by a specially qualified inspector certified by Tremco Inc. shall be provided. A report of the Inspection shall be provided to the City of Los Angeles, Department of Building and Safety's Building Inspector at the conclusion of the installation. The report shall state that the installation complies to all the requirements contained in this research report.

DISCUSSION

The membrane inspection requirement is per Intra-Departmental correspondence issued on October 18, 2005, by Tom Stevens, Assistance Bureau Chief, Inspection Bureau.

Tremco Inc.

RE: TREMproof® 260 for Below-Grade Waterproofing Membrane and Gas Barriers

The approval is based on tests in accordance with the Methane Barrier Test Criteria and Acceptance Criteria for Below-Grade and Exterior Damp-Proofing and Waterproofing Materials.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this Approval have been met in the project in which it is to be used.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

YEUAN CHOU, Chief
Engineering Research Section
2319 Dorris Place
Los Angeles, CA 90031
Phone: (213) 485-2376
Fax: (213) 847-0985

YC:elem
RR25593/wp8.0
R10/12/06
2H6/7104/7105/1402.4

RR 25593
Page 3 of 3