

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

MARSHA L. BROWN
PRESIDENT

HELENA JUBANY
VICE-PRESIDENT

VAN AMBATIELOS
VICTOR H. CUEVAS
ELENORE A. WILLIAMS

CITY OF LOS ANGELES
CALIFORNIA



ANTONIO R. VILLARAIGOSA
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

ROBERT R. "BUD" OVROM
GENERAL MANAGER

RAYMOND S. CHAN, C.E., S.E.
EXECUTIVE OFFICER

Western States Wholesale
1420 Bon View Avenue
Ontario, CA 91761

Attn: Mike Humphreys
(909) 947-0028

RESEARCH REPORT: RR 25481
(CSI # 04060)

Expires: May 1, 2014
Issued Date: March 1, 2011
Code: 2011 LABC

GENERAL APPROVAL – Renewal/Clerical Modification - Super Spec Type S
Masonry Mortar.

DETAILS

The approval is subject to the following conditions:

1. The Type S Masonry Mortar shall be proportioned in accordance with ASTM C 270.
2. The masonry mortars shall be delivered in weatherproof bags. The bags shall be identified by a label indicating the manufacturer's name, product name, the mortar compressive strength at 7 days and 28 days, the net weight, and the minimum and maximum water required.
3. No admixtures shall be used with masonry mortar.
4. There shall be no intermixing of mortars of different deliveries, i.e., mixed in different batches.
5. The mortars shall not be applied at temperatures below 40°F.
6. The mortar shall not be used for foundation or concrete flatwork.
7. No mortar with elapsed time of 90 minutes or more after initial mixing shall be used.

RR 25481
Page 1 of 2

Western States Wholesale
RE: Super Spec Type S Masonry Mortar

8. Tests and sampling shall be conducted as follows:
 - a. Samples shall be taken from every production batch.
 - b. Each sample shall be tested for conformance to Section 4.1 of ASTM C144 with regard to sand gradation.
 - c. Compressive strength tests shall be conducted monthly on a random basis. Specimens shall be cast in two-inch cube molds using recommended water amounts when mixing. 28-day compressive strength test results must exceed minimums set by ASTM C 270.
 - d. All test data shall be documented according to batch numbers.
 - e. All of the above information shall be kept on file with the manufacturer and shall be available to the Department of Building and Safety upon request.
 - f. Tests by a licensed testing agency shall be required per Section 2105.2.2.

DISCUSSION

The clerical modification is to change the contact person and telephone number.

The report is in compliance with the 2011 Los Angeles City Building Code.

This approval is based on tests conducted in accordance with ASTM C-387.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this approval have been met in the project in which it is to be used.

WILLIAM STUTSMAN, Chief
Engineering Research Section
201 N. Figueroa St., Room 880
Los Angeles, CA 90012
Phone- 213-202-9812
Fax- 213-202-9943

KH:kh
RR25481/MSWord2007
R03/07/12
3B1/2103.8