

CITY OF LOS ANGELES

CALIFORNIA

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

—
VAN AMBATIELOS
PRESIDENT

E. FELICIA BRANNON
VICE PRESIDENT

JOSELYN GEAGA-ROSENTHAL
GEORGE HOVAGUIMIAN
JAVIER NUNEZ



ERIC GARCETTI
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

—
FRANK M. BUSH
GENERAL MANAGER

OSAMA YOUNAN, P.E.
EXECUTIVE OFFICER

—
Worthington Armstrong Venture (WAVE)
101 Lindenwood Drive, Suite 350
Malvern, PA 19355

Attn: Jason R. Ameen
(610) 722-1218

Local Representative: Brandon Jensen
(714) 713-1430

RESEARCH REPORT: RR 25913
(CSI #05 40 00)

BASED UPON IAPMO ES
EVALUATION REPORT NO. 0163

REEVALUATION DUE
DATE: October 1, 2020
Issued Date: October 1, 2018
Code: 2017 LABC

GENERAL APPROVAL – Reevaluation/Clerical Modification – Shortspan Drywall Steel Framing System

DETAILS

The above assemblies and/or products are approved when in compliance with the use, description, design, installation, conditions of use, and identification of Report No. 0163, issued January, 2011, revised January 30, 2018, of the IAPMO Evaluation Service, Incorporated. The report, in its entirety, is attached and made part of this general approval.

The parts of Report No. 0163 marked by the asterisks are modified by the Los Angeles City Building Department from this approval.

The approval is subject to the following conditions:

1. Main runners shall be identified by indentation or by nontransferable decal with letters not less than ¼ inch high, and shall include the following information:
 - a. Company name
 - b. Runner designation
 - c. Research Report Number, or Load Rating and Runner Spacing
2. Shortspan drywall steel framing system must be designed and installed per Report No. 0163.

RR 25913
Page 1 of 2

Worthington Armstrong Venture (WAVE)
RE: Shortspan Drywall Steel Framing System

3. Shortspan drywall steel framing system is non-fire rated.
4. The ceiling system is limited to ceilings not considered accessible in accordance with item 28 of Table 1607.1 of the 2017 LABC.

DISCUSSION

The clerical modification is to update the report to the City of Los Angeles Building Code.

This report is in compliance with the 2017 City of Los Angeles Building Code.

The approval is based on tests in accordance with AC 156 and ASTM C645.

This general approval will remain effective provided the Evaluation Report is maintained valid and unrevised with the issuing organization. Any revisions to the report must be submitted to this Department, with appropriate fee, for review in order to continue the approval of the revised report.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this approval have been met in the project in which it is to be used.

QUAN NGHIEM, Chief
Engineering Research Section
201 N. Figueroa St., Room 880
Los Angeles, CA 90012
Phone- 213-202-9812
Fax- 213-202-9943

QN
RR25913/MSWord2013
R09/28/2018
TLB1800241
13.2.5 ASCE 7

Attachments: IAPMO ES Evaluation Report No. 0163 (7 Pages),
Attachment – 3pages (Figures 1-3)