

**BOARD OF
BUILDING AND SAFETY
COMMISSIONERS**

—
JAVIER NUÑEZ
PRESIDENT

MARSHA L. BROWN
VICE-PRESIDENT

VAN AMBATIELOS

PEDRO BIRBA

ELENORE A. WILLIAMS
—

CITY OF LOS ANGELES
CALIFORNIA



—
ANTONIO R. VILLARAIGOSA
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

—
ANDREW A. ADELMAN, P.E.
GENERAL MANAGER

RAYMOND CHAN
EXECUTIVE OFFICER
—

Tremco, Incorporated
3735 Green Road
Beachwood, OH 44122

RESEARCH REPORT: RR 24709
(CSI #07140)

Expires: September 1, 2008

Attn: Wes Hensley
(216) 292-5000

Local Representative:
Gary Wilson
(805) 527-4098

GENERAL APPROVAL - Renewal - Paraseal Waterproofing for below-grade wall and slab waterproofing.

DETAILS

Paraseal is a laminate consisting of a layer of high density polyethylene laminated to approximately one pound per square foot layer of bentonite chips. The waterproofing membrane delivers to the job site in 4' by 4' sheets or 4' by 24' rolls containing in sealed bags identified by the product name and manufacturer.

The above product is approved for below-grade waterproofing as required by Division 14 of the Los Angeles Building Code. The product may be used in conjunction with Los Angeles City approved caulking materials at penetrations of the waterproofing membrane.

The application of the material shall be in accordance with the manufacturer's instructions. A copy of the instruction shall be available at each job site.

DISCUSSION

Satisfactory performance of the product as used on projects in the City of Los Angeles has been submitted. Approval allows the use of the product on a bentonite layer (e.g. shotcrete or gunitite), based on the test report by Southern California Soil and Testing, Incorporated.

RR 24709
Page 1 of 2

Tremco, Incorporated

RE: Paraseal Waterproofing for below-grade wall and slab waterproofing

The membrane was tested to a maximum head of 40 feet of water while maintaining a minimum effective confining fluid pressure of 24 psi.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this Approval have been met in the project in which it is to be used.

YEUAN CHOU, Chief
Engineering Research Section
2319 Dorris Place
Los Angeles, CA 90031
Phone (213) 485-2376
Fax (213) 847-0985

YC:elcm
RR24709/wp8.0
R10/12/06
2H6/1402.4